

**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax


www.sjwatertest.com
NJ DEP Certified Lab #08006

Bancroft School
311 Walton Ave
Mount Laurel, NJ 08054

Results of Lead Analysis

Sample ID:	Sample Location	Date/Time Collected	Date/Time Analyzed	Result	Action Level	Method
U116350	Field Blank	02/21/2022 08:00	02/28/2022 14:50	<2.00	15.5	SM3113B
U116351	Faucet A140	02/21/2022 08:06	02/28/2022 14:57	<2.00	15.5	SM3113B
U116352	Faucet A138	02/21/2022 08:08	02/28/2022 15:04	<2.00	15.5	SM3113B
U116353	Faucet A134	02/21/2022 08:09	02/28/2022 15:10	<2.00	15.5	SM3113B
U116354	Faucet A134A	02/21/2022 08:10	02/28/2022 15:17	<2.00	15.5	SM3113B
U116355	Faucet A134B	02/21/2022 08:11	02/28/2022 15:23	<2.00	15.5	SM3113B
U116356	Faucet A137A	02/21/2022 08:15	02/28/2022 15:43	<2.00	15.5	SM3113B
U116357	Faucet A123B	02/21/2022 08:20	02/28/2022 16:03	<2.00	15.5	SM3113B
U116358	Faucet A123A	02/21/2022 08:21	02/28/2022 16:09	<2.00	15.5	SM3113B
U116359	Faucet A118	02/21/2022 08:22	02/28/2022 16:16	<2.00	15.5	SM3113B
U116360	Faucet A116	02/21/2022 08:24	02/28/2022 16:22	<2.00	15.5	SM3113B
U116361	Faucet A119	02/21/2022 08:26	02/28/2022 16:29	<2.00	15.5	SM3113B
U116362	Faucet A119	02/21/2022 08:27	02/28/2022 16:35	<2.00	15.5	SM3113B
U116363	Faucet A119	02/21/2022 08:28	02/28/2022 16:42	<2.00	15.5	SM3113B
U116364	Faucet A117	02/21/2022 08:29	02/28/2022 17:01	<2.00	15.5	SM3113B
U116365	Faucet A117	02/21/2022 08:30	02/28/2022 17:08	<2.00	15.5	SM3113B
U116366	Faucet A117	02/21/2022 08:31	02/28/2022 17:15	<2.00	15.5	SM3113B
U116367	Faucet A114	02/21/2022 08:33	02/28/2022 17:21	<2.00	15.5	SM3113B
U116368	Faucet A113	02/21/2022 08:34	02/28/2022 17:28	<2.00	15.5	SM3113B
U116369	Faucet A113-2	02/21/2022 08:35	02/28/2022 17:34	<2.00	15.5	SM3113B
U116370	Faucet A113-1	02/21/2022 08:36	02/28/2022 17:41	2.60	15.5	SM3113B
U116371	Faucet A113-B	02/21/2022 08:38	02/28/2022 17:48	<2.00	15.5	SM3113B
U116372	Faucet A113-NS	02/21/2022 08:39	02/28/2022 17:54	<2.00	15.5	SM3113B
U116373	Faucet A113-NS	02/21/2022 08:40	02/28/2022 18:01	<2.00	15.5	SM3113B
U116374	Faucet A113-BR1	02/21/2022 08:42	02/28/2022 18:21	<2.00	15.5	SM3113B
U116375	Faucet A113-BR2	02/21/2022 08:43	02/28/2022 18:40	<2.00	15.5	SM3113B
U116376	Faucet A113-3	02/21/2022 08:44	02/28/2022 18:47	<2.00	15.5	SM3113B
U116377	Faucet A113-P	02/21/2022 08:45	02/28/2022 18:53	3.89	15.5	SM3113B
U116378	Faucet A103	02/21/2022 08:46	02/28/2022 19:00	<2.00	15.5	SM3113B
U116379	Faucet A103	02/21/2022 08:47	02/28/2022 19:06	<2.00	15.5	SM3113B
U116380	Faucet A103	02/21/2022 08:48	02/28/2022 19:13	<2.00	15.5	SM3113B
U116381	Faucet A105	02/21/2022 08:49	02/28/2022 19:19	<2.00	15.5	SM3113B
U116382	Faucet A105	02/21/2022 08:50	03/1/2022 10:49	<2.00	15.5	SM3113B
U116383	Faucet A105	02/21/2022 08:51	03/1/2022 11:08	<2.00	15.5	SM3113B
U116384	Fountain A Wing Hall	02/21/2022 08:52	03/1/2022 11:15	<2.00	15.5	SM3113B
U116385	Faucet A104B	02/21/2022 08:54	03/1/2022 11:21	5.56	15.5	SM3113B
U116386	Faucet A104B	02/21/2022 08:55	03/1/2022 11:28	<2.00	15.5	SM3113B

Units - ug/L = ppb



**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax


www.sjwatertest.com
NJ DEP Certified Lab #08006

Bancroft School
311 Walton Ave
Mount Laurel, NJ 08054

Results of Lead Analysis

Sample ID:	Sample Location	Date/Time Collected	Date/Time Analyzed	Result	Action Level	Method
U116387	Faucet A104B	02/21/2022 08:56	03/1/2022 11:34	<2.00	15.5	SM3113B
U116388	Faucet A104B	02/21/2022 08:57	03/1/2022 11:41	<2.00	15.5	SM3113B
U116389	Faucet A104B	02/21/2022 08:58	03/1/2022 11:47	<2.00	15.5	SM3113B
U116390	Faucet A104B	02/21/2022 08:59	03/1/2022 12:07	<2.00	15.5	SM3113B
U116391	Faucet A104B	02/21/2022 09:00	03/1/2022 12:14	<2.00	15.5	SM3113B
U116392	Faucet A104B	02/21/2022 09:01	03/1/2022 13:26	24.23	15.5	SM3113B
U116393	Faucet A104B	02/21/2022 09:02	03/1/2022 12:20	<2.00	15.5	SM3113B
U116394	Faucet A104B	02/21/2022 09:03	03/1/2022 12:27	<2.00	15.5	SM3113B
U116395	Faucet A104B	02/21/2022 09:04	03/1/2022 12:33	<2.00	15.5	SM3113B
U116396	Faucet A104B	02/21/2022 08:53	03/1/2022 12:40	<2.00	15.5	SM3113B
U116397	Faucet A104C	02/21/2022 09:06	03/1/2022 12:47	<2.00	15.5	SM3113B
U116398	Faucet B100	02/21/2022 09:07	03/1/2022 12:53	<2.00	15.5	SM3113B
U116399	Faucet B100	02/21/2022 09:08	03/1/2022 13:00	<2.00	15.5	SM3113B
U116400	Faucet B100	02/21/2022 09:09	03/1/2022 13:06	<2.00	15.5	SM3113B
U116401	Faucet B100	02/21/2022 09:10	03/1/2022 13:46	13.40	15.5	SM3113B
U116402	Faucet B102	02/21/2022 09:11	03/1/2022 13:52	3.15	15.5	SM3113B
U116403	Faucet B105	02/21/2022 09:12	03/1/2022 13:59	4.35	15.5	SM3113B
U116404	Faucet B105	02/21/2022 09:13	03/1/2022 14:05	<2.00	15.5	SM3113B
U116405	Faucet B106	02/21/2022 09:14	03/1/2022 14:12	8.14	15.5	SM3113B
U116406	Faucet B106	02/21/2022 09:15	03/1/2022 14:18	<2.00	15.5	SM3113B
U116407	Faucet B107	02/21/2022 09:16	03/1/2022 14:25	2.37	15.5	SM3113B
U116408	Faucet B107	02/21/2022 09:17	03/1/2022 15:43	<2.00	15.5	SM3113B
U116409	Faucet B108	02/21/2022 09:18	03/1/2022 14:51	2.27	15.5	SM3113B
U116410	Faucet B108	02/21/2022 09:19	03/1/2022 14:57	<2.00	15.5	SM3113B
U116411	Faucet B110	02/21/2022 09:20	03/1/2022 15:04	<2.00	15.5	SM3113B
U116412	Faucet B110	02/21/2022 09:21	03/1/2022 15:10	<2.00	15.5	SM3113B
U116413	Faucet B112	02/21/2022 09:30	03/1/2022 15:17	2.74	15.5	SM3113B
U116414	Faucet B112	02/21/2022 09:31	03/1/2022 15:24	<2.00	15.5	SM3113B
U116415	Faucet B115	02/21/2022 09:27	03/1/2022 15:30	<2.00	15.5	SM3113B
U116416	Faucet B117	02/21/2022 09:28	03/1/2022 15:37	<2.00	15.5	SM3113B
U116417	Faucet B117	02/21/2022 09:29	03/1/2022 16:03	<2.00	15.5	SM3113B
U116418	Faucet B118	02/21/2022 09:38	03/1/2022 16:10	2.94	15.5	SM3113B
U116419	Faucet B118	02/21/2022 09:39	03/1/2022 16:30	<2.00	15.5	SM3113B
U116420	Faucet B120	02/21/2022 09:43	03/1/2022 16:36	<2.00	15.5	SM3113B
U116421	Faucet B120	02/21/2022 09:44	03/1/2022 16:42	<2.00	15.5	SM3113B
U116422	Faucet B123	02/21/2022 09:33	03/1/2022 16:49	<2.00	15.5	SM3113B
U116423	Faucet B123	02/21/2022 09:34	03/1/2022 16:55	<2.00	15.5	SM3113B

Units - ug/L = ppb



**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwaterest.com
NJ DEP Certified Lab #08006

Bancroft School
311 Walton Ave
Mount Laurel, NJ 08054
Results of Lead Analysis

Sample ID:	Sample Location	Date/Time Collected	Date/Time Analyzed	Result	Action Level	Method
U116424	Faucet B125	02/21/2022 09:35	03/1/2022 17:02	4.00	15.5	SM3113B
U116425	Faucet B125	02/21/2022 09:36	03/1/2022 17:21	<2.00	15.5	SM3113B
U116426	Faucet B127	02/21/2022 09:40	03/1/2022 17:28	2.07	15.5	SM3113B
U116427	Faucet B127	02/21/2022 09:41	03/1/2022 17:35	<2.00	15.5	SM3113B
U116428	Fountain B204	02/21/2022 09:48	03/1/2022 17:41	<2.00	15.5	SM3113B
U116429	Fountain B104	02/21/2022 10:30	03/1/2022 17:48	<2.00	15.5	SM3113B
U116430	Faucet B208	02/21/2022 09:50	03/1/2022 17:54	<2.00	15.5	SM3113B
U116431	Faucet B207	02/21/2022 09:52	03/1/2022 18:01	5.05	15.5	SM3113B
U116432	Faucet B207	02/21/2022 09:53	03/1/2022 18:07	<2.00	15.5	SM3113B
U116433	Faucet B209	02/21/2022 09:57	03/1/2022 18:14	2.13	15.5	SM3113B
U116434	Faucet B209	02/21/2022 09:58	03/1/2022 18:21	<2.00	15.5	SM3113B
U116435	Faucet B210	02/21/2022 09:54	03/1/2022 18:40	3.08	15.5	SM3113B
U116436	Faucet B212	02/21/2022 09:55	03/1/2022 18:47	<2.00	15.5	SM3113B
U116437	Faucet B204	02/21/2022 10:00	03/1/2022 19:07	2.34	15.5	SM3113B
U116438	Faucet B216	02/21/2022 10:01	03/1/2022 19:13	<2.00	15.5	SM3113B
U116439	Faucet B217	02/21/2022 10:06	03/1/2022 19:20	<2.00	15.5	SM3113B
U116440	Faucet B218A	02/21/2022 10:02	03/1/2022 19:26	<2.00	15.5	SM3113B
U116441	Faucet B218B	02/21/2022 10:03	03/1/2022 19:33	<2.00	15.5	SM3113B
U116442	Faucet B225	02/21/2022 10:11	03/1/2022 19:39	3.10	15.5	SM3113B
U116443	Faucet B227	02/21/2022 10:15	03/1/2022 19:59	<2.00	15.5	SM3113B
U116444	Faucet B227	02/21/2022 10:14	03/1/2022 20:06	<2.00	15.5	SM3113B
U116445	Faucet B228	02/21/2022 10:13	03/1/2022 20:12	2.31	15.5	SM3113B
U116446	Faucet B229	02/21/2022 10:18	03/1/2022 20:19	7.50	15.5	SM3113B
U116447	Faucet B230	02/21/2022 10:16	03/1/2022 20:25	<2.00	15.5	SM3113B
U116448	Faucet B232	02/21/2022 10:26	03/1/2022 20:32	6.48	15.5	SM3113B
U116449	Faucet C102	02/21/2022 10:33	03/1/2022 20:39	3.08	15.5	SM3113B
U116450	Faucet C104	02/21/2022 10:35	03/1/2022 20:45	<2.00	15.5	SM3113B
U116451	Faucet C105	02/21/2022 10:36	03/1/2022 20:52	<2.00	15.5	SM3113B
U116452	Faucet C106	02/21/2022 10:38	03/1/2022 20:58	5.72	15.5	SM3113B
U116453	Faucet C106	02/21/2022 10:39	03/3/2022 13:59	<2.00	15.5	SM3113B
U116454	Faucet C108	02/21/2022 10:44	03/3/2022 14:06	3.89	15.5	SM3113B
U116455	Faucet C108	02/21/2022 10:45	03/3/2022 14:12	<2.00	15.5	SM3113B
U116456	Faucet C1112	02/21/2022 10:46	03/3/2022 14:19	2.57	15.5	SM3113B
U116457	Faucet C1112	02/21/2022 10:47	03/3/2022 14:38	<2.00	15.5	SM3113B
U116458	Faucet C105	02/21/2022 10:37	03/3/2022 14:45	<2.00	15.5	SM3113B
U116459	Faucet C107	02/21/2022 10:41	03/3/2022 14:51	<2.00	15.5	SM3113B
U116460	Faucet C107	02/21/2022 10:42	03/3/2022 14:58	<2.00	15.5	SM3113B

Units - ug/L = ppb



**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwaterest.com
NJ DEP Certified Lab #08006

Bancroft School
311 Walton Ave
Mount Laurel, NJ 08054

Results of Lead Analysis

Sample ID:	Sample Location	Date/Time Collected	Date/Time Analyzed	Result	Action Level	Method
U116461	Faucet C114	02/21/2022 10:53	03/3/2022 15:05	<2.00	15.5	SM3113B
U116462	Faucet C118	02/21/2022 11:15	03/3/2022 15:11	<2.00	15.5	SM3113B
U116463	Faucet C109	02/21/2022 10:50	03/3/2022 15:18	38.31	15.5	SM3113B
U116464	Faucet C109	02/21/2022 10:51	03/3/2022 15:24	<2.00	15.5	SM3113B
U116465	Faucet C116	02/21/2022 10:55	03/3/2022 15:31	<2.00	15.5	SM3113B
U116466	Faucet C117	02/21/2022 10:56	03/3/2022 15:38	<2.00	15.5	SM3113B
U116467	Faucet C118	02/21/2022 10:57	03/3/2022 15:58	2.85	15.5	SM3113B
U116468	Faucet C119	02/21/2022 11:06	03/3/2022 16:17	4.19	15.5	SM3113B
U116469	Faucet C120	02/21/2022 11:05	03/3/2022 16:24	<2.00	15.5	SM3113B
U116470	Faucet C121	02/21/2022 11:08	03/3/2022 16:30	<2.00	15.5	SM3113B
U116471	Faucet C126	02/21/2022 11:10	03/3/2022 16:37	23.85	15.5	SM3113B
U116472	Faucet C127	02/21/2022 11:12	03/3/2022 16:43	<2.00	15.5	SM3113B
U116473	Faucet C128	02/21/2022 11:14	03/3/2022 16:49	<2.00	15.5	SM3113B
U116474	Faucet C131	02/21/2022 11:18	03/3/2022 16:56	6.22	15.5	SM3113B
U116475	Faucet C130	02/21/2022 11:17	03/3/2022 17:16	<2.00	15.5	SM3113B
U116476	Faucet C134	02/21/2022 11:22	03/3/2022 17:22	<2.00	15.5	SM3113B
U116477	Faucet C Wing Kitchen	02/21/2022 11:20	03/3/2022 17:29	<2.00	15.5	SM3113B
U116478	Faucet C112	02/21/2022 11:09	03/3/2022 17:35	3.84	15.5	SM3113B

Mark J. Riether, Lab Director

03/15/2022

Date

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006

Customer: Bancroft School
Contact: Steven Hitzel
Address: 311 Walton Ave
 Mount Laurel, NJ 08054
Phone:
Office: Fax:

Lab ID#	Sample Location	Collection Date	Time	Grab	Comp	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
U110350	FIELD BLANK	2/21/22	800	X		D	1 x 250	HNO3*	First Draw Lead	
U110351	FAUCET A140		806	X		D	1 x 250	HNO3*	First Draw Lead	
U110352	FAUCET A138		808	X		D	1 x 250	HNO3*	First Draw Lead	
U110353	COFFEE A134		809	X		D	1 x 250	HNO3*	First Draw Lead	
U110354	FAUCET A134A		810	X		D	1 x 250	HNO3*	First Draw Lead	
U110355	FAUCET A134B		811	X		D	1 x 250	HNO3*	First Draw Lead	
U110356	FAUCET A137A		815	X		D	1 x 250	HNO3*	First Draw Lead	
U110357	FAUCET A123B		820	X		D	1 x 250	HNO3*	First Draw Lead	
U110358	FAUCET A123A		821	X		D	1 x 250	HNO3*	First Draw Lead	
U110359	FAUCET A118		822	X		D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: D: DRINKING WATER A: AQUEOUS S: SOIL SL: SLUDGE G: GROUND WATER S: SURFACE WATER W: WASTE WATER

Turnaround Time	Report Format	Comments/Special Instructions	Cooler Temp
SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Standard		°C
	NJ DEP Reduced Deliverables		
	NJ DEP Full Deliverables	* HNO3 preserved upon receipt at laboratory	Properly Preserved
	Electronic Data Deliverables PWTA Format		Yes No

Sampled by: (Print) <i>Matthew Gocher</i>	Received by: (Signature) <i>[Signature]</i>	Date 2/21/22	Time 1410	Date	Time
Relinquished by: (Signature) <i>[Signature]</i>	Received by: (Signature) <i>[Signature]</i>	Date	Time	Date	Time
Relinquished by: (Signature) <i>[Signature]</i>	Received by: (Signature) <i>[Signature]</i>	Date	Time	Date	Time

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
www.sjwatertest.com
 NJ DEP Certification #08006

Customer: Bancroft School
Contact: Steven Hitzel
Address: 311 Walton Ave
 Mount Laurel, NJ 08054
Phone:
Office: Fax:

Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
U110300	FAUCET A116	2/21/27	829	D	1 x 250	HNO3*	First Draw Lead	
U110301	FAUCET A119		826	D	1 x 250	HNO3*	First Draw Lead	
U110302	FAUCET A119		827	D	1 x 250	HNO3*	First Draw Lead	
U110303	FAUCET A119		828	D	1 x 250	HNO3*	First Draw Lead	
U110304	FAUCET A117		829	D	1 x 250	HNO3*	First Draw Lead	
U110305	FAUCET A117		830	D	1 x 250	HNO3*	First Draw Lead	
U110306	FAUCET A117		831	D	1 x 250	HNO3*	First Draw Lead	
	FOUNTAIN A WING-GYM			D	1 x 250	HNO3*	First Draw Lead	
U110307	FAUCET A114		833	D	1 x 250	HNO3*	First Draw Lead	
U110308	FAUCET A113		834	D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: D=DRINKING WATER A=AQUEOUS S=SOIL SL=SLUDGE GW=GROUND WATER SWS=SURFACE WATER WW=WASTE WATER

Turnaround Time	Report Format	Comments/Special Instructions	Cooler Temp
<input type="checkbox"/> Standard <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format			°C
SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____		* HNO3 preserved upon receipt at laboratory	Properly Preserved
			Yes No

Sampled by: (Print) <i>Matthew Gordon</i>	Date	Time	Received by:	Date	Time
Sampled by/Relinquished by: (Signature) <i>[Signature]</i>	2/21/27	1410	(Signature)		
Relinquished by: (Signature) _____	Date	Time	Received by: (Signature)	Date	Time
Relinquished by: (Signature) _____	Date	Time	Received by: (Signature)	Date	Time

CHAIN OF CUSTODY RECORD

Customer: Bancroft School
Contact: Steven Hitzel
Address: 311 Walton Ave
 Mount Laurel, NJ 08054
Phone:
Office:

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
www.sjwatertest.com
 NJ DEP Certification #08006



Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
U116369	FAUCET A113-2	2/21/22	835	D	1 x 250	HNO3*	First Draw Lead	
U116370	FAUCET A113-1		836	D	1 x 250	HNO3*	First Draw Lead	
U116371	FAUCET A113-B		838	D	1 x 250	HNO3*	First Draw Lead	
U116372	FAUCET A113-NS		839	D	1 x 250	HNO3*	First Draw Lead	
U116373	FAUCET A113-NS		840	D	1 x 250	HNO3*	First Draw Lead	
U116374	FAUCET A113-BR1		842	D	1 x 250	HNO3*	First Draw Lead	
U116375	FAUCET A113-BR2		843	D	1 x 250	HNO3*	First Draw Lead	
U116376	FAUCET A113-3		844	D	1 x 250	HNO3*	First Draw Lead	
U116377	FAUCET A113-P		845	D	1 x 250	HNO3*	First Draw Lead	
U116378	FAUCET A103		846	D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: D=DRINKING WATER A=AQUEOUS S=SOIL SL=SLUDGE GW=GROUND WATER SW=SURFACE WATER WW=WASTE WATER

Turnaround Time SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Report Format Standard NJ DEP Reduced Deliverables NJ DEP Full Deliverables Electronic Data Deliverables PWTA Format	Comments/Special Instructions * HNO3 preserved upon receipt at laboratory	Cooler Temp °C
	Properly Preserved Yes No		

Sampled by: *Matthew Giesler*
 (Print) _____
Sampled by/Relinquished by: _____
 (Signature) _____ Date 2/21/22 Time 1416
Relinquished by: _____
 (Signature) _____ Date _____ Time _____
Relinquished by: _____
 (Signature) _____ Date _____ Time _____

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC

4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
www.sjwatertest.com
 NJ DEP Certification #08006

Customer: Bancroft School
 Contact: Steven Hitzel
 Address: 311 Walton Ave
 Mount Laurel, NJ 08054
 Phone: Fax:
 Office:

Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
U110379	FAUCET A103	2/21/22	847	D	1 x 250	HNO3*	First Draw Lead	
U110380	FAUCET A103		848	D	1 x 250	HNO3*	First Draw Lead	
U110381	FAUCET A105		849	D	1 x 250	HNO3*	First Draw Lead	
U110382	FAUCET A105		850	D	1 x 250	HNO3*	First Draw Lead	
U110383	FAUCET A105		851	D	1 x 250	HNO3*	First Draw Lead	
U110384	FOUNTAIN A WING HALL		852	D	1 x 250	HNO3*	First Draw Lead	
U110385	FAUCET A104B		854	D	1 x 250	HNO3*	First Draw Lead	
U110380	FAUCET A104B		855	D	1 x 250	HNO3*	First Draw Lead	
U110387	FAUCET A104B		856	D	1 x 250	HNO3*	First Draw Lead	
U110388	FAUCET A104B		857	D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: D=DRINKING WATER A=AQUEOUS S=SOIL SL=SLUDGE G=GROUND WATER SW=SURFACE WATER WW=WASTE WATER

Turnaround Time	Report Format	Comments/Special Instructions	Cooler Temp
SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Standard NJ DEP Reduced Deliverables NJ DEP Full Deliverables Electronic Data Deliverables PWTA Format	* HNO3 preserved upon receipt at laboratory	°C Properly Preserved Yes No

Sampled by: *Matthew Gordon*
 (Print)
 Sampled by/Relinquished by: *Matthew Gordon*
 (Signature) Date: 2/21/22 Time: 1410
 Relinquished by: _____
 (Signature) Date: _____ Time: _____
 Relinquished by: _____
 (Signature) Date: _____ Time: _____

Received by:	Date	Time
<i>Matthew Gordon</i> (Signature)	2/21/22	1410
_____	_____	_____
_____	_____	_____

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC

4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
www.sjwatertest.com
 NJ DEP Certification #08006

Customer: Bancroft School
 Contact: Steven Hitzel
 Address: 311 Walton Ave
 Mount Laurel, NJ 08054
 Phone: Fax:
 Office:

Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
U110389	FAUCET A104B	2/21/22	858	D	1 x 250	HNO3*	First Draw Lead	
U110390	FAUCET A104B		859	D	1 x 250	HNO3*	First Draw Lead	
U110391	FAUCET A104B		800	D	1 x 250	HNO3*	First Draw Lead	
U110392	FAUCET A104B		901	D	1 x 250	HNO3*	First Draw Lead	
U110393	FAUCET A104B		902	D	1 x 250	HNO3*	First Draw Lead	
U110394	FAUCET A104B		903	D	1 x 250	HNO3*	First Draw Lead	
U110395	FAUCET A104B		904	D	1 x 250	HNO3*	First Draw Lead	
U110396	FAUCET A104B		893	D	1 x 250	HNO3*	First Draw Lead	
U110397	FAUCET A104C		906	D	1 x 250	HNO3*	First Draw Lead	
U110398	FAUCET B100		907	D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: D: DRINKING WATER A: AQUEOUS S: SOIL SL: SLUDGE G: GROUND WATER S: SURFACE WATER W: WASTE WATER

Turnaround Time	Report Format	Comments/Special Instructions	Cooler Temp
SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Standard		°C
	NJ DEP Reduced Deliverables	* HNO3 preserved upon receipt at laboratory	Properly Preserved
	NJ DEP Full Deliverables		Yes
	Electronic Data Deliverables		No
	PWTA Format		

Sampled by: <i>Matthew Coda</i>	Received by: _____	Date: _____	Time: _____
Sampled by/Relinquished by: _____	Received by: _____	Date: _____	Time: _____
Relinquished by: _____	Received by: _____	Date: _____	Time: _____
Relinquished by: _____	Received by: _____	Date: _____	Time: _____

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
www.sjwatertest.com
 NJ DEP Certification #08006

Customer: Bancroft School
Contact: Steven Hitzel
Address: 311 Walton Ave
 Mount Laurel, NJ 08054
Phone:
Office: Fax:

Lab ID#	Sample Location	Collection Date	Time	Grab	Comp	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
U116399	FAUCET B100	2/21/22	908	X		D	1 x 250	HNO3*	First Draw Lead	
U116400	FAUCET B100		909	X		D	1 x 250	HNO3*	First Draw Lead	
U116401	FAUCET B100		910	X		D	1 x 250	HNO3*	First Draw Lead	
U116402	FAUCET B102		911	X		D	1 x 250	HNO3*	First Draw Lead	
U116403	FAUCET B105		912	X		D	1 x 250	HNO3*	First Draw Lead	
U116404	FAUCET B105		913	X		D	1 x 250	HNO3*	First Draw Lead	
U116405	FAUCET B106		914	X		D	1 x 250	HNO3*	First Draw Lead	
U116406	FAUCET B106		915	X		D	1 x 250	HNO3*	First Draw Lead	
U116407	FAUCET B107		916	X		D	1 x 250	HNO3*	First Draw Lead	
U116408	FAUCET B107		917	X		D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: D: DRINKING WATER A: AQUEOUS S: SOIL SL: SLUDGE G: GROUND WATER S: SURFACE WATER W: WASTE WATER

Turnaround Time S:JW Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Report Format Standard NJ DEP Reduced Deliverables NJ DEP Full Deliverables Electronic Data Deliverables PWTA Format	Comments/Special Instructions * HNO3 preserved upon receipt at laboratory	Cooler Temp °C
	Properly Preserved Yes No		

Sampled by: (Print) <i>Matthew Gordin</i>	Received by: (Signature) <i>[Signature]</i>	Date 2/21/22	Time 1410
Relinquished by: (Signature) <i>[Signature]</i>	Received by: (Signature) <i>[Signature]</i>	Date	Time
Relinquished by: (Signature) <i>[Signature]</i>	Received by: (Signature) <i>[Signature]</i>	Date	Time

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
www.sjwatertest.com
 NJ DEP Certification #08006

Customer: Bancroft School
Contact: Steven Hitzel
Address: 311 Walton Ave
 Mount Laurel, NJ 08054
Phone:
Office:

Lab ID#	Sample Location	Collection Date	Collection Time	Com p o n e n t	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
U110409	FAUCET B108	2/21/12	918	X	D	1 x 250	HNO3*	First Draw Lead	
U110410	FAUCET B108		919	X	D	1 x 250	HNO3*	First Draw Lead	
U110411	FAUCET B110		920	X	D	1 x 250	HNO3*	First Draw Lead	
U110412	FAUCET B110		921	X	D	1 x 250	HNO3*	First Draw Lead	
U110413	FAUCET B112		930	X	D	1 x 250	HNO3*	First Draw Lead	
U110414	FAUCET B112		931	X	D	1 x 250	HNO3*	First Draw Lead	
U110415	FAUCET B115		927	X	D	1 x 250	HNO3*	First Draw Lead	
U110416	FAUCET B117		928	X	D	1 x 250	HNO3*	First Draw Lead	
U110417	FAUCET B117		929	X	D	1 x 250	HNO3*	First Draw Lead	
U110418	FAUCET B118		938	X	D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER AIAQUEOUS SISOIL SLI SLUDGE GW/GROUND WATER SWS/SURFACE WATER WWM/WASTE WATER

Turnaround Time	Report Format	Comments/Special Instructions	Cooler Temp
6-JWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Standard NJ DEP Reduced Deliverables NJ DEP Full Deliverables Electronic Data Deliverables PWTA Format	* HNO3 preserved upon receipt at laboratory	Properly Preserved Yes No

Sampled by: (Print) <i>Matthew Gordon</i>	Received by: (Signature) <i>[Signature]</i>	Date 2/21/12	Time	Date	Time
Relinquished by: (Signature) <i>[Signature]</i>	Received by: (Signature)	Date	Time	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Time	Date	Time

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
www.sjwaterest.com
 NJ DEP Certification #08006

Customer: Bancroft School
Contact: Steven Hitzel
Address: 311 Walton Ave
 Mount Laurel, NJ 08054
Phone:
Office: Fax:

Lab ID#	Sample Location	Collection Date	Collection Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
U110419	FAUCET B118	2/21/22	9:39	D	1 x 250	HNO3*	First Draw Lead	
U110420	FAUCET B120		9:43	D	1 x 250	HNO3*	First Draw Lead	
U110421	FAUCET B120		9:44	D	1 x 250	HNO3*	First Draw Lead	
U110422	FAUCET B123		9:33	D	1 x 250	HNO3*	First Draw Lead	
U110423	FAUCET B123		9:34	D	1 x 250	HNO3*	First Draw Lead	
U110424	FAUCET B125		9:35	D	1 x 250	HNO3*	First Draw Lead	
U110425	FAUCET B125		9:36	D	1 x 250	HNO3*	First Draw Lead	
U110426	FAUCET B127		9:40	D	1 x 250	HNO3*	First Draw Lead	
U110427	FAUCET B127		9:41	D	1 x 250	HNO3*	First Draw Lead	
U110428	FAUCET B104		9:48	D	1 x 250	HNO3*	First Draw Lead	

U110429 Fountain B104 10:30
 MATRIX ABBREVIATIONS: DIDRINKING WATER AQUEOUS SISOIL SL/SLUDGE GW/GROUND WATER SWS/SURFACE WATER WW/WASTE WATER
 HNO3* First Draw Lead

Turnaround Time	Report Format	Comments/Special Instructions	Cooler Temp
<input checked="" type="checkbox"/> SJWT Standard is 10-20 work days <input type="checkbox"/> Rush turnaround available upon request and lab approval _____	Standard <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	* HNO3 preserved upon receipt at laboratory Yes No	<input type="checkbox"/> °C <input type="checkbox"/> Properly Preserved Yes No

Sampled by: (Print) <i>Matthew Corda</i>	Received by: (Signature) <i>[Signature]</i>	Date 2/21/22	Date Time
Relinquished by: (Signature) _____	Received by: (Signature) _____	Date Time	Date Time
Relinquished by: (Signature) _____	Received by: (Signature) _____	Date Time	Date Time

CHAIN OF CUSTODY RECORD

Customer: Bancroft School
Contact: Steven Hitzel
Address: 311 Walton Ave
 Mount Laurel, NJ 08054
Phone:
Office:

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006



Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
U110430	FAUCET B200	2/21/22	950	D	1 x 250	HNO3*	First Draw Lead	
U110431	FAUCET B207		952	D	1 x 250	HNO3*	First Draw Lead	
U110432	FAUCET B207		953	D	1 x 250	HNO3*	First Draw Lead	
U110433	FAUCET B209		957	D	1 x 250	HNO3*	First Draw Lead	
U110434	FAUCET B209		958	D	1 x 250	HNO3*	First Draw Lead	
U110435	FAUCET B210		954	D	1 x 250	HNO3*	First Draw Lead	
U110436	FAUCET B212		955	D	1 x 250	HNO3*	First Draw Lead	
U110437	FAUCET B214		1000	D	1 x 250	HNO3*	First Draw Lead	
U110438	FAUCET B216		1001	D	1 x 250	HNO3*	First Draw Lead	
U110439	FAUCET B217		1006	D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: D: DRINKING WATER A: AQUEOUS S: SOIL SL: SLUDGE G: GROUND WATER SW: SURFACE WATER WW: WASTE WATER

Turnaround Time <input checked="" type="checkbox"/> SJWT Standard is 10-20 work days <input type="checkbox"/> Rush turnaround available upon request and lab approval _____	Report Format Standard <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	Comments/Special Instructions * HNO3 preserved upon receipt at laboratory	Cooler Temp _____ °C
	Properly Preserved Yes _____ No _____		

Sampled by: *Matthew Becker*

Sampled by/Relinquished by: _____
 (Signature) _____
 Date: 2/21/22 Time: 1410

Relinquished by: _____
 (Signature) _____
 Date: _____ Time: _____

Relinquished by: _____
 (Signature) _____
 Date: _____ Time: _____

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
www.sjwatertest.com
 NJ DEP Certification #08006

Customer: Bancroft School
Contact: Steven Hitzel
Address: 311 Walton Ave
 Mount Laurel, NJ 08054
Phone:
Office:

Lab ID#	Sample Location	Collection Date	Time	Grab	Comp	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
U116440	FAUCET FOUNTAIN-B218A	2/21	1002	X		D	1 x 250	HNO3*	First Draw Lead	
U116441	FAUCET B218B		1003	X		D	1 x 250	HNO3*	First Draw Lead	
	FAUCET B220			X		D	1 x 250	HNO3*	First Draw Lead	
	FAUCET B223			X		D	1 x 250	HNO3*	First Draw Lead	
U116442	FAUCET B225		1011	X		D	1 x 250	HNO3*	First Draw Lead	
U116443	FAUCET B227		1015	X		D	1 x 250	HNO3*	First Draw Lead	
U116444	FAUCET B227		1014	X		D	1 x 250	HNO3*	First Draw Lead	
U116445	FAUCET B228		1013	X		D	1 x 250	HNO3*	First Draw Lead	
U116446	FAUCET B229		1018	X		D	1 x 250	HNO3*	First Draw Lead	
U116447	FAUCET B230		1016	X		D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: D/D DRINKING WATER A/A AQUEOUS S/S SOIL S/L SLUDGE G/W GROUND WATER S/W SURFACE WATER W/W WASTE WATER

Turnaround Time ___ SJWT Standard is 10-20 work days ___ Rush turnaround available upon request and lab approval ___	Report Format ___ Standard ___ NJ DEP Reduced Deliverables ___ NJ DEP Full Deliverables ___ Electronic Data Deliverables ___ PWTA Format	Comments/Special Instructions * HNO3 preserved upon receipt at laboratory	Cooler Temp ___ °C
	Properly Preserved Yes No		

Sampled by: *Matthew Gerdner*

Sampled by/Relinquished by: *Matthew Gerdner*

Relinquished by: _____

Relinquished by: _____

Date	Time	Received by:	Date	Time
2/21/22	1410	(Signature)		
Date	Time	Received by:	Date	Time
		(Signature)		
Date	Time	Received by:	Date	Time
		(Signature)		

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
www.sjwatertest.com
 NJ DEP Certification #08006

Customer: Bancroft School
Contact: Steven Hitzel
Address: 311 Walton Ave
 Mount Laurel, NJ 08054
Phone:
Office: Fax:

Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
U116448	FAUCET B232	2/21/22	1036	D	1 x 250	HNO3*	First Draw Lead	
U116449	FOUNTAIN C102		1033	D	1 x 250	HNO3*	First Draw Lead	
U116450	FAUCET C104		1035	D	1 x 250	HNO3*	First Draw Lead	
U116451	FAUCET C105		1036	D	1 x 250	HNO3*	First Draw Lead	
U116452	FAUCET C106		1038	D	1 x 250	HNO3*	First Draw Lead	
U116453	FAUCET C106		1039	D	1 x 250	HNO3*	First Draw Lead	
U116454	FAUCET C108		1044	D	1 x 250	HNO3*	First Draw Lead	
U116455	FAUCET C108		1045	D	1 x 250	HNO3*	First Draw Lead	
U116456	FAUCET C1112		1046	D	1 x 250	HNO3*	First Draw Lead	
U116457	FAUCET C1112		1047	D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER AQUEOUS SISOIL SLISLUDGE GWIGROUND WATER SWSURFACE WATER WWWASTE WATER

Turnaround Time	Report Format	Comments/Special Instructions	Cooler Temp
SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Standard NJ DEP Reduced Deliverables NJ DEP Full Deliverables Electronic Data Deliverables PWTA Format	* HNO3 preserved upon receipt at laboratory	Properly Preserved Yes No

Sampled by: *Matthew Gachow*
 (Print)
 Sampled by/Relinquished by: *[Signature]*
 (Signature) Date: 2/21/22 Time: 1410
 Relinquished by: _____
 (Signature) Date: _____ Time: _____
 Relinquished by: _____
 (Signature) Date: _____ Time: _____

Received by:	Date	Time
<i>[Signature]</i>	2/21/22	1410
_____	_____	_____
_____	_____	_____

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
www.sjwatertest.com
 NJ DEP Certification #08006

Customer: Bancroft School
Contact: Steven Hitzel
Address: 311 Walton Ave
 Mount Laurel, NJ 08054
Phone:
Office:

Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
U110458	FAUCET C106 C105	2/21/22	1037	D	1 x 250	HNO3*	First Draw Lead	
U110459	FAUCET C406 C107		1041	D	1 x 250	HNO3*	First Draw Lead	
U110460	FAUCET C406 C107		1042	D	1 x 250	HNO3*	First Draw Lead	
U110461	FAUCET C406 C114		1053	D	1 x 250	HNO3*	First Draw Lead	
U110462	FAUCET C406 C118		1115	D	1 x 250	HNO3*	First Draw Lead	
	FAUCET C107			D	1 x 250	HNO3*	First Draw Lead	
	FAUCET C108			D	1 x 250	HNO3*	First Draw Lead	
U110463	FAUCET C109		1050	D	1 x 250	HNO3*	First Draw Lead	
U110464	FAUCET C109		1051	D	1 x 250	HNO3*	First Draw Lead	
U110465	FAUCET C415		1055	D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: D: DRINKING WATER A: AQUEOUS S: SOIL SL: SLUDGE G: GROUND WATER S: SURFACE WATER W: WASTE WATER

Turnaround Time SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Report Format Standard NJ DEP Reduced Deliverables NJ DEP Full Deliverables Electronic Data Deliverables PWTA Format	Comments/Special Instructions * HNO3 preserved upon receipt at laboratory	Cooler Temp °C
	Properly Preserved Yes No		

Sampled by: *Matthew Gordon*

Sampled by/Relinquished by: _____
 (Signature)

Relinquished by: _____
 (Signature)

Relinquished by: _____
 (Signature)

Date	Time	Received by:	Date	Time
2/21/22	1410	(Signature)		
Date	Time	Received by:	Date	Time
		(Signature)		
Date	Time	Received by:	Date	Time
		(Signature)		

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC

4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
www.sjwatertest.com
 NJ DEP Certification #08006

Customer: Bancroft School
 Contact: Steven Hitzel
 Address: 311 Walton Ave
 Mount Laurel, NJ 08054
 Phone: _____ Fax: _____
 Office: _____

Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
U1104106	FAUCET C116	2/21/22	1055	D	1 x 250	HNO3*	First Draw Lead	
U1104107	FAUCET C117	1056		D	1 x 250	HNO3*	First Draw Lead	
U1104108	FAUCET C118	1057		D	1 x 250	HNO3*	First Draw Lead	
U1104109	FAUCET C119	1106		D	1 x 250	HNO3*	First Draw Lead	
U1104110	FAUCET C120	1105		D	1 x 250	HNO3*	First Draw Lead	
U1104111	FAUCET C121	1108		D	1 x 250	HNO3*	First Draw Lead	
U1104112	FAUCET C126	1110		D	1 x 250	HNO3*	First Draw Lead	
U1104113	FAUCET C127	1112		D	1 x 250	HNO3*	First Draw Lead	
U1104114	FAUCET C128	1114		D	1 x 250	HNO3*	First Draw Lead	
U1104115	FAUCET C132	1118		D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER AQUEOUS S/SOIL SL/SLUDGE GW/GROUND WATER SWS/SURFACE WATER WW/WASTE WATER

Turnaround Time	Report Format	Comments/Special Instructions	Cooler Temp
<input type="checkbox"/> Standard <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	<input type="checkbox"/> Standard <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	* HNO3 preserved upon receipt at laboratory Yes No	°C

Sampled by: *Matthew Godwin*
 (Print)
 Sampled by/Relinquished by: _____
 (Signature)
 Relinquished by: _____
 (Signature)
 Relinquished by: _____
 (Signature)

Date	Time	Received by:	Date	Time	Received by:
2/21/22		(Signature)			(Signature)
		(Signature)			(Signature)
		(Signature)			(Signature)

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
www.sjwatertest.com
 NJ DEP Certification #08006

Customer: Bancroft School
Contact: Steven Hitzel
Address: 311 Walton Ave
 Mount Laurel, NJ 08054
Phone:
Office: Fax:

Lab ID#	Sample Location	Collection Date	Collection Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
U116479	FAUCET C131	2/21/22	1118	D	1 x 250	HNO3*	First Draw Lead	
U116475	FAUCET C130		1117	D	1 x 250	HNO3*	First Draw Lead	
U116476	FAUCET C134		1122	D	1 x 250	HNO3*	First Draw Lead	
U116478	FAUCET C WING KITCHEN		1120	D	1 x 250	HNO3*	First Draw Lead	
U116478	FAUCET C122		1109	D	1 x 250	HNO3*	First Draw Lead	
				D	1 x 250	HNO3*	First Draw Lead	
				D	1 x 250	HNO3*	First Draw Lead	
				D	1 x 250	HNO3*	First Draw Lead	
				D	1 x 250	HNO3*	First Draw Lead	
				D	1 x 250	HNO3*	First Draw Lead	
				D	1 x 250	HNO3*	First Draw Lead	
				D	1 x 250	HNO3*	First Draw Lead	
				D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: D: DRINKING WATER A: AQUEOUS S: SOIL SL: SLUDGE G: GROUND WATER SW: SURFACE WATER W: WASTE WATER

Turnaround Time	Report Format	Comments/Special Instructions	Cooler Temp
SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Standard NJ DEP Reduced Deliverables NJ DEP Full Deliverables Electronic Data Deliverables PWTA Format	* HNO3 preserved upon receipt at laboratory	Properly Preserved Yes No

Sampled by: <i>Matthew Cordeiro</i> (Print)	Received by: _____ (Signature)	Date: 2/21/22 Time: 1410	Date: _____ Time: _____
Relinquished by: _____ (Signature)	Received by: _____ (Signature)	Date: _____ Time: _____	Date: _____ Time: _____
Relinquished by: _____ (Signature)	Received by: _____ (Signature)	Date: _____ Time: _____	Date: _____ Time: _____