



**South Jersey  
Water Test, LLC**

4077 South Black Horse Pike  
Williamstown, NJ 08094  
856-875-3506 Phone  
856-875-3507 Fax

www.sjwatertest.com  
NJ DEP Certified Lab #08006

**Bancroft PEEP**  
101 Executive Drive  
Moorestown, NJ 08057

## Results of Lead Analysis

Sample ID:	Sample Location	Date/Time Collected	Date/Time Analyzed	Result	Action Level	Method
U116315	Field Blank	02/21/2022 11:50	02/24/2022 17:18	<2.00	15.5	SM3113B
U116316	Faucet 107	02/21/2022 11:55	02/24/2022 17:25	<2.00	15.5	SM3113B
U116317	Faucet 108	02/21/2022 11:56	02/24/2022 17:32	<2.00	15.5	SM3113B
U116318	Faucet 109	02/21/2022 11:58	02/24/2022 17:38	<2.00	15.5	SM3113B
U116319	Faucet 111A	02/21/2022 11:57	02/24/2022 17:45	3.74	15.5	SM3113B
U116320	Faucet 112	02/21/2022 11:59	02/24/2022 17:52	<2.00	15.5	SM3113B
U116321	Faucet 112	02/21/2022 12:00	02/24/2022 17:58	<2.00	15.5	SM3113B
U116322	Faucet 112	02/21/2022 12:01	02/24/2022 18:05	<2.00	15.5	SM3113B
U116323	Faucet 112	02/21/2022 12:02	02/24/2022 18:11	<2.00	15.5	SM3113B
U116324	Faucet 112	02/21/2022 12:03	02/24/2022 18:31	4.38	15.5	SM3113B
U116325	Faucet 113	02/21/2022 12:04	02/24/2022 18:51	2.17	15.5	SM3113B
U116326	Faucet 113	02/21/2022 12:05	02/24/2022 18:58	4.41	15.5	SM3113B
U116327	Faucet 113	02/21/2022 12:06	02/24/2022 19:04	<2.00	15.5	SM3113B
U116328	Faucet 113	02/21/2022 12:07	02/24/2022 19:10	<2.00	15.5	SM3113B
U116329	Faucet 113	02/21/2022 12:08	02/24/2022 19:17	<2.00	15.5	SM3113B
U116330	Fountain 119 Hall	02/21/2022 12:09	02/24/2022 19:23	2.24	15.5	SM3113B
U116331	Slop Sink 119 Laundry	02/21/2022 12:10	02/24/2022 19:30	3.32	15.5	SM3113B
U116332	Faucet 126	02/21/2022 12:11	02/28/2022 12:46	55.31	15.5	SM3113B
U116333	Faucet 126	02/21/2022 12:12	02/28/2022 13:25	<2.00	15.5	SM3113B
U116334	Faucet 126	02/21/2022 12:13	02/28/2022 13:06	<2.00	15.5	SM3113B
U116335	Faucet 126	02/21/2022 12:14	02/28/2022 13:32	3.55	15.5	SM3113B
U116336	Faucet 126	02/21/2022 12:15	02/28/2022 13:38	<2.00	15.5	SM3113B
U116337	Faucet 127	02/21/2022 12:16	02/28/2022 13:45	4.60	15.5	SM3113B
U116338	Faucet 127	02/21/2022 12:17	02/28/2022 13:51	3.46	15.5	SM3113B
U116339	Faucet 127	02/21/2022 12:18	02/28/2022 13:58	12.78	15.5	SM3113B
U116340	Faucet 127	02/21/2022 12:19	02/28/2022 14:04	<2.00	15.5	SM3113B
U116341	Faucet 127	02/21/2022 12:20	02/28/2022 14:24	7.60	15.5	SM3113B
U116342	Faucet 134	02/21/2022 12:21	02/28/2022 14:31	<2.00	15.5	SM3113B
U116343	Faucet 134	02/21/2022 12:22	02/28/2022 14:37	3.16	15.5	SM3113B
U116344	Faucet 139B	02/21/2022 12:23	02/28/2022 14:44	<2.00	15.5	SM3113B

Mark J. Riether, Lab Director

03/01/2022

Date

Units - ug/L = ppb

CHAIN OF CUSTODY RECORD

**South Jersey Water Test, LLC**  
 4077 South Black Horse Pike  
 Williamstown, NJ 08094  
 Phone: 856-875-3506 Fax: 856-875-3507  
 www.sjwatertest.com  
 NJ DEP Certification #08006

**Customer:** Bancroft Peep  
**Contact:** Steven Hitzel  
**Address:** 101 Executive Drive  
 Moorestown, NJ 08057  
**Phone:**  
**Office:**

Lab ID#	Sample Location	Collection Date	Time	Lab	Comp	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
U110315	FIELD BLANK	2/21/22	1150	X		D	1 x 250	HNO3*	First Draw Lead	
U110316	FAUCET 107		1155	X		D	1 x 250	HNO3*	First Draw Lead	
U110317	FAUCET 108		1156	X		D	1 x 250	HNO3*	First Draw Lead	
U110318	FAUCET 109		1158	X		D	1 x 250	HNO3*	First Draw Lead	
U110319	FAUCET 111A		1157	X		D	1 x 250	HNO3*	First Draw Lead	
U110320	FAUCET 112		1159	X		D	1 x 250	HNO3*	First Draw Lead	
U110321	FAUCET 112		1200	X		D	1 x 250	HNO3*	First Draw Lead	
U110322	FAUCET 112		1201	X		D	1 x 250	HNO3*	First Draw Lead	
U110323	FAUCET 112		1202	X		D	1 x 250	HNO3*	First Draw Lead	
U110324	FAUCET 112		1203	X		D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: D: DRINKING WATER A: AQUEOUS S: SOIL SL: SLUDGE G: GROUND WATER SW: SURFACE WATER W: WASTE WATER

Turnaround Time	Report Format	Comments/Special Instructions	Cooler Temp
<input type="checkbox"/> SJWT Standard is 10-20 work days <input type="checkbox"/> Rush turnaround available upon request and lab approval _____	Standard <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	* HNO3 preserved upon receipt at laboratory Yes _____ No _____	_____ °C

<b>Sampled by:</b> (Print) <i>Matthew Cordw</i>	<b>Received by:</b> (Signature) <i>[Signature]</i>	<b>Date</b> 2/21	<b>Time</b> 1410
<b>Relinquished by:</b> (Signature) <i>[Signature]</i>	<b>Received by:</b> (Signature) <i>[Signature]</i>	<b>Date</b>	<b>Time</b>
<b>Relinquished by:</b> (Signature) <i>[Signature]</i>	<b>Received by:</b> (Signature) <i>[Signature]</i>	<b>Date</b>	<b>Time</b>

CHAIN OF CUSTODY RECORD

**South Jersey Water Test, LLC**  
 4077 South Black Horse Pike  
 Williamstown, NJ 08094  
 Phone: 856-875-3506 Fax: 856-875-3507  
 www.sjwatertest.com  
 NJ DEP Certification #08006

**Customer:** Bancroft Peep  
**Contact:** Steven Hitzel  
**Address:** 101 Executive Drive  
 Moorestown, NJ 08057  
**Phone:**  
**Office:**

Lab ID#	Sample Location	Collection Date	Time	G Lab	Comp	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
U110335	FAUCET 113	2/21/22	1204	X		D	1 x 250	HNO3*	First Draw Lead	
U110336	FAUCET 113		1205	X		D	1 x 250	HNO3*	First Draw Lead	
U110337	FAUCET 113		1206	X		D	1 x 250	HNO3*	First Draw Lead	
U110338	FAUCET 113		1207	X		D	1 x 250	HNO3*	First Draw Lead	
U110339	FAUCET 113		1208	X		D	1 x 250	HNO3*	First Draw Lead	
U110340	FOUNTAIN 119HALL		1209	X		D	1 x 250	HNO3*	First Draw Lead	
U110341	SLOP SINK 119LAUNDRY		1210	X		D	1 x 250	HNO3*	First Draw Lead	
U110342	FAUCET 126		1211	X		D	1 x 250	HNO3*	First Draw Lead	
U110343	FAUCET 126		1212	X		D	1 x 250	HNO3*	First Draw Lead	
U110344	FAUCET 126		1213	X		D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER A/AQUEOUS S/SOIL S/LSLUDGE G/WGROUND WATER S/WSURFACE WATER W/WWASTE WATER

Turnaround Time	Report Format	Comments/Special Instructions	Cooler Temp
SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Standard NJ DEP Reduced Deliverables NJ DEP Full Deliverables Electronic Data Deliverables PWTA Format	* HNO3 preserved upon receipt at laboratory	°C Properly Preserved Yes No

Sampled by: (Print) <i>Matthew Guedes</i>	Received by: (Signature) <i>[Signature]</i>	Date 2/21/22	Time 1410
Relinquished by: (Signature) _____	Received by: (Signature) _____	Date	Time
Relinquished by: (Signature) _____	Received by: (Signature) _____	Date	Time

CHAIN OF CUSTODY RECORD

**South Jersey Water Test, LLC**  
 4077 South Black Horse Pike  
 Williamstown, NJ 08094  
 Phone: 856-875-3506 Fax: 856-875-3507  
[www.sjwatertest.com](http://www.sjwatertest.com)  
 NJ DEP Certification #08006

**Customer:** Bancroft Peep  
**Contact:** Steven Hitzel  
**Address:** 101 Executive Drive  
 Moorestown, NJ 08057  
**Phone:**  
**Office:**

Lab ID#	Sample Location	Collection Date	Time	Grab	Comp	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
U116325	FAUCET 126	12/21/22	12:14	X		D	1 x 250	HNO3*	First Draw Lead	
U116326	FAUCET 126		12:15	X		D	1 x 250	HNO3*	First Draw Lead	
U116327	FAUCET 127		12:16	X		D	1 x 250	HNO3*	First Draw Lead	
U116328	FAUCET 127		12:17	X		D	1 x 250	HNO3*	First Draw Lead	
U116329	FAUCET 127		12:18	X		D	1 x 250	HNO3*	First Draw Lead	
U116330	FAUCET 127		12:19	X		D	1 x 250	HNO3*	First Draw Lead	
U116331	FAUCET 127		12:20	X		D	1 x 250	HNO3*	First Draw Lead	
U116332	FAUCET 134		12:21	X		D	1 x 250	HNO3*	First Draw Lead	
U116333	FAUCET 134		12:22	X		D	1 x 250	HNO3*	First Draw Lead	
U116334	FAUCET 139B		12:23	X		D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER AWAQUEOUS SISOIL SL/SLUDGE GWIGROUND WATER SWSURFACE WATER WWWWASTE WATER

Turnaround Time	Report Format	Comments/Special Instructions	Cooler Temp
<input type="checkbox"/> Standard <input checked="" type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format		* HNO3 preserved upon receipt at laboratory	°C
SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____			Properly Preserved
			Yes
			No

<b>Sampled by:</b> (Print) <i>Matthew Ordine</i>	Date	Time	Received by:	Date	Time
(Signature)	12/21/22		(Signature)		
<b>Relinquished by:</b> (Signature)	Date	Time	Received by:	Date	Time
(Signature)			(Signature)		
<b>Relinquished by:</b> (Signature)	Date	Time	Received by:	Date	Time
(Signature)			(Signature)		