



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

Bancroft School
311 Walton Ave
Mount Laurel, NJ 08054

www.sjwatertest.com
NJ DEP Certified Lab # 08006

Sample Location: Field Blank

Date Sampled: 08/22/24

Time Sampled: 08:00

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141540					
Lead	26-AUG-2024 13:30	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet A140

Date Sampled: 08/22/24

Time Sampled: 10:00

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141541					
Lead	26-AUG-2024 13:36	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet A138

Date Sampled: 08/22/24

Time Sampled: 10:05

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141542					
Lead	26-AUG-2024 13:43	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Coffee A134

Date Sampled: 08/22/24

Time Sampled: 10:06

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141543					
Lead	26-AUG-2024 13:50	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet A134A

Date Sampled: 08/22/24

Time Sampled: 10:07

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141544					
Lead	26-AUG-2024 13:56	21.13	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet A134B

Date Sampled: 08/22/24

Time Sampled: 10:08

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141545					
Lead	26-AUG-2024 14:03	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet A137A

Date Sampled: 08/22/24

Time Sampled: 10:10

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141546					
Lead	26-AUG-2024 14:10	3.06	ug/L	2.0	15.5	SM3113B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

09/04/2024

Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

Bancroft School
311 Walton Ave
Mount Laurel, NJ 08054

www.sjwatertest.com
NJ DEP Certified Lab # 08006

Sample Location: Faucet A123B

Date Sampled: 08/22/24

Time Sampled: 10:11

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141547					
Lead	26-AUG-2024 14:16	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet A123A

Date Sampled: 08/22/24

Time Sampled: 10:12

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141548					
Lead	26-AUG-2024 14:23	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet A118

Date Sampled: 08/22/24

Time Sampled: 10:13

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141549					
Lead	26-AUG-2024 14:30	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet A116

Date Sampled: 08/22/24

Time Sampled: 10:14

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141550					
Lead	26-AUG-2024 14:50	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet A119

Date Sampled: 08/22/24

Time Sampled: 10:15

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141551					
Lead	26-AUG-2024 15:09	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet A119

Date Sampled: 08/22/24

Time Sampled: 10:16

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141552					
Lead	26-AUG-2024 15:16	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet A119

Date Sampled: 08/22/24

Time Sampled: 10:17

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141553					
Lead	26-AUG-2024 15:22	<2.00	ug/L	2.0	15.5	SM3113B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

09/04/2024

Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

Bancroft School
311 Walton Ave
Mount Laurel, NJ 08054

www.sjwatertest.com
NJ DEP Certified Lab # 08006

Sample Location: Faucet A117

Date Sampled: 08/22/24

Time Sampled: 10:18

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141554					
Lead	26-AUG-2024 15:29	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet A117

Date Sampled: 08/22/24

Time Sampled: 10:19

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141555					
Lead	26-AUG-2024 15:35	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet A117

Date Sampled: 08/22/24

Time Sampled: 10:20

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141556					
Lead	26-AUG-2024 15:42	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Fountain A Wing Gym

Date Sampled: 08/22/24

Time Sampled: 10:21

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141557					
Lead	26-AUG-2024 15:48	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet A114

Date Sampled: 08/22/24

Time Sampled: 10:22

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141558					
Lead	26-AUG-2024 16:08	6.01	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet A113

Date Sampled: 08/22/24

Time Sampled: 10:23

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141559					
Lead	26-AUG-2024 16:15	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet A113-2

Date Sampled: 08/22/24

Time Sampled: 10:24

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141560					
Lead	26-AUG-2024 16:21	<2.00	ug/L	2.0	15.5	SM3113B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

09/04/2024

Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

Bancroft School
311 Walton Ave
Mount Laurel, NJ 08054

www.sjwatertest.com
NJ DEP Certified Lab # 08006

Sample Location: Faucet A113-1

Date Sampled: 08/22/24

Time Sampled: 10:25

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141561					
Lead	26-AUG-2024 16:28	8.97	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet A113-B

Date Sampled: 08/22/24

Time Sampled: 10:26

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141562					
Lead	26-AUG-2024 16:34	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet A113-NS

Date Sampled: 08/22/24

Time Sampled: 10:27

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141563					
Lead	26-AUG-2024 16:41	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet A113-NS

Date Sampled: 08/22/24

Time Sampled: 10:28

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141564					
Lead	26-AUG-2024 16:48	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet A113-BR1

Date Sampled: 08/22/24

Time Sampled: 10:29

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141565					
Lead	26-AUG-2024 16:54	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet A113-BR2

Date Sampled: 08/22/24

Time Sampled: 10:30

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141566					
Lead	26-AUG-2024 17:01	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet A113-3

Date Sampled: 08/22/24

Time Sampled: 10:31

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141567					
Lead	26-AUG-2024 17:08	<2.00	ug/L	2.0	15.5	SM3113B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

09/04/2024

Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

Bancroft School
311 Walton Ave
Mount Laurel, NJ 08054

www.sjwatertest.com
NJ DEP Certified Lab # 08006

Sample Location: Faucet A113-P

Date Sampled: 08/22/24

Time Sampled: 10:32

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141568					
Lead	27-AUG-2024 09:31	2.79	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet 103

Date Sampled: 08/22/24

Time Sampled: 10:33

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141569					
Lead	27-AUG-2024 09:51	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet A103

Date Sampled: 08/22/24

Time Sampled: 10:34

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141570					
Lead	27-AUG-2024 09:57	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet A103

Date Sampled: 08/22/24

Time Sampled: 10:35

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141571					
Lead	27-AUG-2024 10:04	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet A105

Date Sampled: 08/22/24

Time Sampled: 10:36

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141572					
Lead	27-AUG-2024 10:10	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet A105

Date Sampled: 08/22/24

Time Sampled: 10:37

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141573					
Lead	27-AUG-2024 10:17	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet A105

Date Sampled: 08/22/24

Time Sampled: 10:38

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141574					
Lead	27-AUG-2024 10:23	<2.00	ug/L	2.0	15.5	SM3113B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

09/04/2024

Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

Bancroft School
311 Walton Ave
Mount Laurel, NJ 08054

www.sjwatertest.com
NJ DEP Certified Lab # 08006

Sample Location: Fountain A Wing Hall

Date Sampled: 08/22/24

Time Sampled: 10:39

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141575					
Lead	27-AUG-2024 10:30	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet A104B

Date Sampled: 08/22/24

Time Sampled: 10:40

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141576					
Lead	27-AUG-2024 10:50	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet A104B

Date Sampled: 08/22/24

Time Sampled: 10:41

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141577					
Lead	27-AUG-2024 10:56	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet A104B

Date Sampled: 08/22/24

Time Sampled: 10:42

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141578					
Lead	27-AUG-2024 11:03	5.08	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet A104B

Date Sampled: 08/22/24

Time Sampled: 10:43

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141579					
Lead	27-AUG-2024 11:09	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet A104B

Date Sampled: 08/22/24

Time Sampled: 10:44

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141580					
Lead	27-AUG-2024 11:16	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet A104B

Date Sampled: 08/22/24

Time Sampled: 10:51

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141581					
Lead	27-AUG-2024 11:23	<2.00	ug/L	2.0	15.5	SM3113B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

09/04/2024

Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

Bancroft School
311 Walton Ave
Mount Laurel, NJ 08054

www.sjwatertest.com
NJ DEP Certified Lab # 08006

Sample Location: Faucet A104B

Date Sampled: 08/22/24

Time Sampled: 10:52

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141582					
Lead	27-AUG-2024 11:29	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet A104B

Date Sampled: 08/22/24

Time Sampled: 10:53

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141583					
Lead	27-AUG-2024 11:36	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet A104B

Date Sampled: 08/22/24

Time Sampled: 10:56

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141584					
Lead	27-AUG-2024 11:43	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet A104B

Date Sampled: 08/22/24

Time Sampled: 10:57

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141585					
Lead	27-AUG-2024 11:49	5.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet A104B

Date Sampled: 08/22/24

Time Sampled: 10:59

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141586					
Lead	27-AUG-2024 12:09	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet A104B

Date Sampled: 08/22/24

Time Sampled: 10:50

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141587					
Lead	27-AUG-2024 12:29	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet A104C

Date Sampled: 08/22/24

Time Sampled: 11:00

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141588					
Lead	27-AUG-2024 12:36	<2.00	ug/L	2.0	15.5	SM3113B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

09/04/2024

Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

Bancroft School
311 Walton Ave
Mount Laurel, NJ 08054

www.sjwatertest.com
NJ DEP Certified Lab # 08006

Sample Location: Faucet B100

Date Sampled: 08/22/24

Time Sampled: 08:56

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141589					
Lead	27-AUG-2024 12:42	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet B100

Date Sampled: 08/22/24

Time Sampled: 08:53

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141590					
Lead	27-AUG-2024 12:49	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet B100

Date Sampled: 08/22/24

Time Sampled: 08:54

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141591					
Lead	27-AUG-2024 12:55	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet B100

Date Sampled: 08/22/24

Time Sampled: 08:55

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141592					
Lead	27-AUG-2024 13:02	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet B102

Date Sampled: 08/22/24

Time Sampled: 08:57

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141593					
Lead	27-AUG-2024 13:08	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet B105

Date Sampled: 08/22/24

Time Sampled: 08:59

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141594					
Lead	27-AUG-2024 13:28	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet B105

Date Sampled: 08/22/24

Time Sampled: 09:00

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141595					
Lead	27-AUG-2024 13:35	<2.00	ug/L	2.0	15.5	SM3113B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

09/04/2024

Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

Bancroft School
311 Walton Ave
Mount Laurel, NJ 08054

www.sjwatertest.com
NJ DEP Certified Lab # 08006

Sample Location: Faucet B106

Date Sampled: 08/22/24

Time Sampled: 09:01

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141596					
Lead	27-AUG-2024 13:41	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet B106

Date Sampled: 08/22/24

Time Sampled: 09:02

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141597					
Lead	27-AUG-2024 13:48	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet B107

Date Sampled: 08/22/24

Time Sampled: 09:03

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141598					
Lead	27-AUG-2024 13:54	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet B107

Date Sampled: 08/22/24

Time Sampled: 09:04

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141599					
Lead	27-AUG-2024 14:01	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet B108

Date Sampled: 08/22/24

Time Sampled: 09:05

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141600					
Lead	27-AUG-2024 14:08	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet B108

Date Sampled: 08/22/24

Time Sampled: 09:06

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141601					
Lead	27-AUG-2024 14:15	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet B110

Date Sampled: 08/22/24

Time Sampled: 09:07

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141602					
Lead	27-AUG-2024 14:21	<2.00	ug/L	2.0	15.5	SM3113B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

09/04/2024

Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

Bancroft School
311 Walton Ave
Mount Laurel, NJ 08054

www.sjwatertest.com
NJ DEP Certified Lab # 08006

Sample Location: Faucet B110

Date Sampled: 08/22/24

Time Sampled: 09:08

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141603					
Lead	27-AUG-2024 14:28	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet B112

Date Sampled: 08/22/24

Time Sampled: 09:09

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141604					
Lead	27-AUG-2024 14:48	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet B112

Date Sampled: 08/22/24

Time Sampled: 09:10

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141605					
Lead	27-AUG-2024 15:07	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet B115

Date Sampled: 08/22/24

Time Sampled: 09:11

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141606					
Lead	27-AUG-2024 15:14	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet B117

Date Sampled: 08/22/24

Time Sampled: 09:12

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141607					
Lead	27-AUG-2024 15:20	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet B117

Date Sampled: 08/22/24

Time Sampled: 09:13

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141608					
Lead	27-AUG-2024 15:27	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet B118

Date Sampled: 08/22/24

Time Sampled: 09:14

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141609					
Lead	27-AUG-2024 15:34	<2.00	ug/L	2.0	15.5	SM3113B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

09/04/2024

Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

Bancroft School
311 Walton Ave
Mount Laurel, NJ 08054

www.sjwatertest.com
NJ DEP Certified Lab # 08006

Sample Location: Faucet B118

Date Sampled: 08/22/24

Time Sampled: 09:15

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141610					
Lead	27-AUG-2024 15:40	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet B120

Date Sampled: 08/22/24

Time Sampled: 09:16

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141611					
Lead	27-AUG-2024 15:46	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet B120

Date Sampled: 08/22/24

Time Sampled: 09:17

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141612					
Lead	27-AUG-2024 16:06	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet B123

Date Sampled: 08/22/24

Time Sampled: 09:18

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141613					
Lead	27-AUG-2024 16:13	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet B123

Date Sampled: 08/22/24

Time Sampled: 09:19

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141614					
Lead	27-AUG-2024 16:19	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet B125

Date Sampled: 08/22/24

Time Sampled: 09:20

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141615					
Lead	27-AUG-2024 16:26	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet B125

Date Sampled: 08/22/24

Time Sampled: 09:21


Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141616					
Lead	27-AUG-2024 16:33	<2.00	ug/L	2.0	15.5	SM3113B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

09/04/2024

Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

Bancroft School
311 Walton Ave
Mount Laurel, NJ 08054

www.sjwatertest.com
NJ DEP Certified Lab # 08006

Sample Location: Faucet B127

Date Sampled: 08/22/24

Time Sampled: 09:22

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141617					
Lead	27-AUG-2024 16:39	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet B127

Date Sampled: 08/22/24

Time Sampled: 09:23

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141618					
Lead	27-AUG-2024 16:46	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet B104

Date Sampled: 08/22/24

Time Sampled: 08:52

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141619					
Lead	27-AUG-2024 16:53	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet B207

Date Sampled: 08/22/24

Time Sampled: 08:49

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141620					
Lead	27-AUG-2024 16:59	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet B207

Date Sampled: 08/22/24

Time Sampled: 08:48

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141621					
Lead	27-AUG-2024 17:06	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet B209 1

Date Sampled: 08/22/24

Time Sampled: 08:47

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141622					
Lead	29-AUG-2024 12:17	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet B209 2

Date Sampled: 08/22/24

Time Sampled: 08:46

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141623					
Lead	29-AUG-2024 12:36	<2.00	ug/L	2.0	15.5	SM3113B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

09/04/2024

Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

Bancroft School
311 Walton Ave
Mount Laurel, NJ 08054

www.sjwatertest.com
NJ DEP Certified Lab # 08006

Sample Location: Faucet B210

Date Sampled: 08/22/24

Time Sampled: 08:45

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141624					
Lead	29-AUG-2024 12:43	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet B212

Date Sampled: 08/22/24

Time Sampled: 08:44

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141625					
Lead	29-AUG-2024 12:49	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet B214

Date Sampled: 08/22/24

Time Sampled: 08:43

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141626					
Lead	29-AUG-2024 12:56	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet B216

Date Sampled: 08/22/24

Time Sampled: 08:42

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141627					
Lead	29-AUG-2024 13:02	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet B217

Date Sampled: 08/22/24

Time Sampled: 08:41

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141628					
Lead	29-AUG-2024 13:09	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet B218A

Date Sampled: 08/22/24

Time Sampled: 08:39

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141629					
Lead	29-AUG-2024 13:15	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet B218B

Date Sampled: 08/22/24

Time Sampled: 08:38

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141630					
Lead	29-AUG-2024 13:35	<2.00	ug/L	2.0	15.5	SM3113B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

09/04/2024

Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

Bancroft School
311 Walton Ave
Mount Laurel, NJ 08054

www.sjwatertest.com
NJ DEP Certified Lab # 08006

Sample Location: Faucet B220

Date Sampled: 08/22/24

Time Sampled: 08:37

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141631					
Lead	29-AUG-2024 13:42	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet B223

Date Sampled: 08/22/24

Time Sampled: 08:36

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141632					
Lead	29-AUG-2024 13:49	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet B225

Date Sampled: 08/22/24

Time Sampled: 08:35

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141633					
Lead	29-AUG-2024 13:55	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet B227 2

Date Sampled: 08/22/24

Time Sampled: 08:34

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141634					
Lead	29-AUG-2024 14:02	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet B227 1

Date Sampled: 08/22/24

Time Sampled: 08:33

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141635					
Lead	29-AUG-2024 14:09	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet B228

Date Sampled: 08/22/24

Time Sampled: 08:32

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141636					
Lead	29-AUG-2024 14:15	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet B229

Date Sampled: 08/22/24

Time Sampled: 08:31


Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141637					
Lead	29-AUG-2024 14:22	<2.00	ug/L	2.0	15.5	SM3113B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

09/04/2024

Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

Bancroft School
311 Walton Ave
Mount Laurel, NJ 08054

www.sjwatertest.com
NJ DEP Certified Lab # 08006

Sample Location: Faucet B230

Date Sampled: 08/22/24

Time Sampled: 08:30

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141638					
Lead	29-AUG-2024 14:29	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet B232

Date Sampled: 08/22/24

Time Sampled: 08:40

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141639					
Lead	29-AUG-2024 14:35	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: B Kitchen Lounge

Date Sampled: 08/22/24

Time Sampled: 08:50

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141640					
Lead	29-AUG-2024 14:55	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: B Upstairs Fountain

Date Sampled: 08/22/24

Time Sampled: 08:51

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141641					
Lead	29-AUG-2024 15:15	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: B Downstairs Fountain

Date Sampled: 08/22/24

Time Sampled: 08:58

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141642					
Lead	29-AUG-2024 15:22	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet C102A

Date Sampled: 08/22/24

Time Sampled: 09:25

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141643					
Lead	29-AUG-2024 15:28	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet C102B

Date Sampled: 08/22/24

Time Sampled: 09:26

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141644					
Lead	29-AUG-2024 15:35	<2.00	ug/L	2.0	15.5	SM3113B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

09/04/2024

Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

Bancroft School
311 Walton Ave
Mount Laurel, NJ 08054

www.sjwatertest.com
NJ DEP Certified Lab # 08006

Sample Location: Faucet C104

Date Sampled: 08/22/24

Time Sampled: 09:27

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141645					
Lead	29-AUG-2024 15:41	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet C107

Date Sampled: 08/22/24

Time Sampled: 09:35

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141646					
Lead	29-AUG-2024 15:48	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet C108

Date Sampled: 08/22/24

Time Sampled: 09:36

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141647					
Lead	29-AUG-2024 15:54	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet C101 A

Date Sampled: 08/22/24

Time Sampled: 09:57

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141648					
Lead	3-SEP-2024 12:03	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet C105

Date Sampled: 08/22/24

Time Sampled: 09:28

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141649					
Lead	3-SEP-2024 12:10	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet C105

Date Sampled: 08/22/24

Time Sampled: 09:29

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141650					
Lead	3-SEP-2024 12:17	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet C106

Date Sampled: 08/22/24

Time Sampled: 09:31

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141651					
Lead	3-SEP-2024 12:23	2.40	ug/L	2.0	15.5	SM3113B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

09/04/2024

Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

Bancroft School
311 Walton Ave
Mount Laurel, NJ 08054

www.sjwatertest.com
NJ DEP Certified Lab # 08006

Sample Location: Faucet C106

Date Sampled: 08/22/24

Time Sampled: 09:32

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141652					
Lead	3-SEP-2024 12:30	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet C107

Date Sampled: 08/22/24

Time Sampled: 09:33

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141653					
Lead	3-SEP-2024 12:37	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet C108

Date Sampled: 08/22/24

Time Sampled: 09:34

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141654					
Lead	3-SEP-2024 12:43	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet C109

Date Sampled: 08/22/24

Time Sampled: 09:37

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141655					
Lead	3-SEP-2024 13:23	2.21	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet C109

Date Sampled: 08/22/24

Time Sampled: 09:38

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141656					
Lead	3-SEP-2024 13:04	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet C114

Date Sampled: 08/22/24

Time Sampled: 09:40

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141657					
Lead	3-SEP-2024 13:30	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet C116

Date Sampled: 08/22/24

Time Sampled: 09:41

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141658					
Lead	3-SEP-2024 13:36	<2.00	ug/L	2.0	15.5	SM3113B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

09/04/2024

Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

Bancroft School
311 Walton Ave
Mount Laurel, NJ 08054

www.sjwatertest.com
NJ DEP Certified Lab # 08006

Sample Location: Faucet C117

Date Sampled: 08/22/24

Time Sampled: 09:42

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141659					
Lead	3-SEP-2024 13:43	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet C118

Date Sampled: 08/22/24

Time Sampled: 09:43

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141660					
Lead	3-SEP-2024 13:49	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet C119

Date Sampled: 08/22/24

Time Sampled: 09:44

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141661					
Lead	3-SEP-2024 13:56	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet C120

Date Sampled: 08/22/24

Time Sampled: 09:45

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141662					
Lead	3-SEP-2024 14:02	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet C121

Date Sampled: 08/22/24

Time Sampled: 09:46

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141663					
Lead	3-SEP-2024 14:22	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet C126

Date Sampled: 08/22/24

Time Sampled: 09:47

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141664					
Lead	3-SEP-2024 14:29	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet C127

Date Sampled: 08/22/24

Time Sampled: 09:48

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141665					
Lead	3-SEP-2024 14:35	<2.00	ug/L	2.0	15.5	SM3113B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

09/04/2024

Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

Bancroft School
311 Walton Ave
Mount Laurel, NJ 08054

www.sjwatertest.com
NJ DEP Certified Lab # 08006

Sample Location: Faucet C128

Date Sampled: 08/22/24

Time Sampled: 09:49

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141666					
Lead	3-SEP-2024 14:42	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet C131

Date Sampled: 08/22/24

Time Sampled: 09:51

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141667					
Lead	3-SEP-2024 14:48	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet C130

Date Sampled: 08/22/24

Time Sampled: 09:52

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141668					
Lead	3-SEP-2024 14:55	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet C134

Date Sampled: 08/22/24

Time Sampled: 09:53

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141669					
Lead	3-SEP-2024 15:02	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet C Wing Kitchen

Date Sampled: 08/22/24

Time Sampled: 09:54

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141670					
Lead	3-SEP-2024 15:08	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet C100

Date Sampled: 08/22/24

Time Sampled: 09:56

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141671					
Lead	3-SEP-2024 15:15	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet C112

Date Sampled: 08/22/24

Time Sampled: 09:40

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141672					
Lead	3-SEP-2024 15:22	<2.00	ug/L	2.0	15.5	SM3113B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

09/04/2024

Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

Bancroft School
311 Walton Ave
Mount Laurel, NJ 08054

www.sjwatertest.com
NJ DEP Certified Lab # 08006

Sample Location: Faucet C112

Date Sampled: 08/22/24

Time Sampled: 09:41

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141673					
Lead	3-SEP-2024 16:02	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet C122

Date Sampled: 08/22/24

Time Sampled: 09:47

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141674					
Lead	3-SEP-2024 15:42	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet C128

Date Sampled: 08/22/24

Time Sampled: 09:50

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141675					
Lead	3-SEP-2024 16:08	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Faucet C101

Date Sampled: 08/22/24

Time Sampled: 09:55

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141676					
Lead	3-SEP-2024 16:15	<2.00	ug/L	2.0	15.5	SM3113B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

09/04/2024

Date

CHAIN OF CUSTODY RECORD

Customer: Bancroft School
Contact: Steven Hitzel
Address: 311 Walton Ave
 Mount Laurel, NJ 08054
Phone:
Office: Fax:

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
www.sjwatertest.com
 NJ DEP Certification #08006



Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
W141540	FIELD BLANK	8/22/24		D	1 x 250	HNO3*	First Draw Lead	
W141541	FAUCET A140		1000	D	1 x 250	HNO3*	First Draw Lead	
W141542	FAUCET A138		1005	D	1 x 250	HNO3*	First Draw Lead	
W141543	COFFEE A134		1006	D	1 x 250	HNO3*	First Draw Lead	
W141544	FAUCET A134A		1007	D	1 x 250	HNO3*	First Draw Lead	
W141545	FAUCET A134B		1008	D	1 x 250	HNO3*	First Draw Lead	
W141546	FAUCET A137A		1015	D	1 x 250	HNO3*	First Draw Lead	
W141547	FAUCET A123B		1011	D	1 x 250	HNO3*	First Draw Lead	
W141548	FAUCET A123A		1012	D	1 x 250	HNO3*	First Draw Lead	
W141549	FAUCET A118		1013	D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: D: DRINKING WATER A: AQUEOUS S: SOIL SL: SLUDGE G: GROUND WATER SW: SURFACE WATER WW: WASTE WATER

Turnaround Time
 SJWT Standard is 10-20 work days
 Rush turnaround available upon request and lab approval _____

Report Format
 Standard
 NJ DEP Reduced Deliverables
 NJ DEP Full Deliverables
 Electronic Data Deliverables
 PWTA Format

Comments/Special Instructions
 * HNO3 preserved upon receipt at laboratory

Cooler Temp
 °C
 Properly Preserved
 Yes No

Sampled by: *D. Maggini*
 (Print)
Sampled by/Relinquished by:
 (Signature)
Relinquished by:
 (Signature)
Relinquished by:
 (Signature)

Date	Time	Received by:	Date	Time
8/22/24	1400	(Signature)	8/22/24	1400
		(Signature)		
		(Signature)		

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006

Customer: Bancroft School
Contact: Steven Hitzel
Address: 311 Walton Ave
 Mount Laurel, NJ 08054
Phone:
Office:

Lab ID#	Sample Location	Collection Date	Time	g	g	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
W141550	FAUCET A116	8/22/24	1014	X		D	1 x 250	HNO3*	First Draw Lead	
W141551	FAUCET A119		1015	X		D	1 x 250	HNO3*	First Draw Lead	
W141552	FAUCET A119		1016	X		D	1 x 250	HNO3*	First Draw Lead	
W141553	FAUCET A119		1017	X		D	1 x 250	HNO3*	First Draw Lead	
W141554	FAUCET A117		1018	X		D	1 x 250	HNO3*	First Draw Lead	
W141555	FAUCET A117		1019	X		D	1 x 250	HNO3*	First Draw Lead	
W141556	FAUCET A117		1020	X		D	1 x 250	HNO3*	First Draw Lead	
W141557	FOUNTAIN A WING GYM		1021	X		D	1 x 250	HNO3*	First Draw Lead	
W141558	FAUCET A114		1022	X		D	1 x 250	HNO3*	First Draw Lead	
W141559	FAUCET A113		1023	X		D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: D: DRINKING WATER A: AQUEOUS S: SOIL SL: SLUDGE G: GROUND WATER S: SURFACE WATER W: WASTE WATER

Turnaround Time SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Report Format <input checked="" type="checkbox"/> Standard <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	Comments/Special Instructions	Cooler Temp
		* HNO3 preserved upon receipt at laboratory Yes _____ No _____	°C

Sampled by: D. Mancini

Sampled by/Relinquished by: [Signature] Date: 8/22/24 Time: 1400

Relinquished by: _____ Date: _____ Time: _____

Relinquished by: _____ Date: _____ Time: _____

CHAIN OF CUSTODY RECORD

Customer: Bancroft School
Contact: Steven Hitzel
Address: 311 Walton Ave
 Mount Laurel, NJ 08054
Phone:
Office:

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006



Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
W141500	FAUCET A113-2	8/22/04	1024	D	1 x 250	HNO3*	First Draw Lead	
W141501	FAUCET A113-1		1025	D	1 x 250	HNO3*	First Draw Lead	
W141502	FAUCET A113-B		1026	D	1 x 250	HNO3*	First Draw Lead	
W141503	FAUCET A113-NS		1027	D	1 x 250	HNO3*	First Draw Lead	
W141504	FAUCET A113-NS		1028	D	1 x 250	HNO3*	First Draw Lead	
W141505	FAUCET A113-BR1		1029	D	1 x 250	HNO3*	First Draw Lead	
W141506	FAUCET A113-BR2		1030	D	1 x 250	HNO3*	First Draw Lead	
W141507	FAUCET A113-3		1031	D	1 x 250	HNO3*	First Draw Lead	
W141508	FAUCET A113-P		1032	D	1 x 250	HNO3*	First Draw Lead	
W141509	FAUCET A103		1033	D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: D:D RINKING WATER A: AQUEOUS S: SOIL S: SLUDGE G: GROUND WATER S: SURFACE WATER W: WASTE WATER

Turnaround Time SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Report Format <input checked="" type="checkbox"/> Standard <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	Comments/Special Instructions * HNO3 preserved upon receipt at laboratory	Cooler Temp °C
	Properly Preserved Yes No		

Sampled by: <u>D. Mancini</u> (Print)	Received by: _____ (Signature)	Date: <u>8/22/04</u>	Date: <u>8/22/04</u>	Time: <u>1400</u>	Time: <u>1700</u>
Relinquished by: _____ (Signature)	Received by: _____ (Signature)	Date: _____	Date: _____	Time: _____	Time: _____
Relinquished by: _____ (Signature)	Received by: _____ (Signature)	Date: _____	Date: _____	Time: _____	Time: _____

CHAIN OF CUSTODY RECORD

Customer: Bancroft School
Contact: Steven Hitzel
Address: 311 Walton Ave
 Mount Laurel, NJ 08054
Phone:
Office:

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
www.sjwatertest.com
 NJ DEP Certification #08006



Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
W141570	FAUCET A103	8/22/24	1034	D	1 x 250	HNO3*	First Draw Lead	
W141571	FAUCET A103		1035	D	1 x 250	HNO3*	First Draw Lead	
W141572	FAUCET A105		1036	D	1 x 250	HNO3*	First Draw Lead	
W141573	FAUCET A105		1037	D	1 x 250	HNO3*	First Draw Lead	
W141574	FAUCET A105		1038	D	1 x 250	HNO3*	First Draw Lead	
W141575	FOUNTAIN A WING HALL		1039	D	1 x 250	HNO3*	First Draw Lead	
W141576	FAUCET A104B		1040	D	1 x 250	HNO3*	First Draw Lead	
W141577	FAUCET A104B		1041	D	1 x 250	HNO3*	First Draw Lead	
W141578	FAUCET A104B		1042	D	1 x 250	HNO3*	First Draw Lead	
W141579	FAUCET A104B		1043	D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: D: DRINKING WATER A: AQUEOUS S: SOIL SL: SLUDGE GW: GROUND WATER SW: SURFACE WATER WW: WASTE WATER

Turnaround Time <input checked="" type="checkbox"/> SJWT Standard is 10-20 work days <input type="checkbox"/> Rush turnaround available upon request and lab approval _____	Report Format <input checked="" type="checkbox"/> Standard <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	Comments/Special Instructions * HNO3 preserved upon receipt at laboratory		Cooler Temp °C Yes No

Sampled by: <i>D. Mancini</i> (Print)	Received by: (Signature)	Date: 8/22/24 Date	Date: 8/22/24 Date	Time: 1400 Time	Time: <i>1:00 PM</i> Time
Relinquished by: (Signature)	Received by: (Signature)	Date: Date	Date: Date	Time: Time	Time: Time
Relinquished by: (Signature)	Received by: (Signature)	Date: Date	Date: Date	Time: Time	Time: Time

CHAIN OF CUSTODY RECORD

Customer: Bancroft School
Contact: Steven Hitzel
Address: 311 Walton Ave
 Mount Laurel, NJ 08054
Phone:
Office:

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006



Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
W141580	FAUCET A104B	8/22/24	1044	D	1 x 250	HNO3*	First Draw Lead	
W141581	FAUCET A104B		1051	D	1 x 250	HNO3*	First Draw Lead	
W141582	FAUCET A104B		1052	D	1 x 250	HNO3*	First Draw Lead	
W141583	FAUCET A104B		1053	D	1 x 250	HNO3*	First Draw Lead	
W141584	FAUCET A104B		1056	D	1 x 250	HNO3*	First Draw Lead	
W141585	FAUCET A104B		1057	D	1 x 250	HNO3*	First Draw Lead	
W141586	FAUCET A104B		1059	D	1 x 250	HNO3*	First Draw Lead	
W141587	FAUCET A104B		1050	D	1 x 250	HNO3*	First Draw Lead	
W141588	FAUCET A104C		1100	D	1 x 250	HNO3*	First Draw Lead	
W141589	FAUCET B100		0856	D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: D: DRINKING WATER A: AQUEOUS S: SOIL S: SLUDGE G: GROUND WATER S: SURFACE WATER W: WASTE WATER

Turnaround Time SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Report Format <input checked="" type="checkbox"/> Standard <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	Comments/Special Instructions * HNO3 preserved upon receipt at laboratory	Cooler Temp 1 °C
<input type="checkbox"/> Yes <input type="checkbox"/> No			

Sampled by: *D. Mancini*
 (Print)

Sampled by/Relinquished by: *D. Mancini*
 (Signature)

Relinquished by: _____
 (Signature)

Relinquished by: _____
 (Signature)

Date 8/22/24	Time 1400	Received by: (Signature)	Date <i>8/22/24</i>	Time <i>1400</i>
Date	Time	Received by: (Signature)	Date	Time
Date	Time	Received by: (Signature)	Date	Time

CHAIN OF CUSTODY RECORD

Customer: Bancroft School
Contact: Steven Hitzel
Address: 311 Walton Ave
 Mount Laurel, NJ 08054
Phone:
Office:

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006



Lab ID#	Sample Location	Collection Date	Time	Temp	Pres.	No. of Bottles	Analysis Requested	Comments
W141590	FAUCET B100	8/22/24	0853	X	D	1 x 250	HNO3* First Draw Lead	
W141591	FAUCET B100		0654	X	D	1 x 250	HNO3* First Draw Lead	
W141592	FAUCET B100		0855	X	D	1 x 250	HNO3* First Draw Lead	
W141593	FAUCET B102		0857	X	D	1 x 250	HNO3* First Draw Lead	
W141594	FAUCET B105		0859	X	D	1 x 250	HNO3* First Draw Lead	
W141595	FAUCET B105		0900	X	D	1 x 250	HNO3* First Draw Lead	
W141596	FAUCET B106		0901	X	D	1 x 250	HNO3* First Draw Lead	
W141597	FAUCET B106		0902	X	D	1 x 250	HNO3* First Draw Lead	
W141598	FAUCET B107		0903	X	D	1 x 250	HNO3* First Draw Lead	
W141599	FAUCET B107		0904	X	D	1 x 250	HNO3* First Draw Lead	

MATRIX ABBREVIATIONS: D: DRINKING WATER A: AQUEOUS S: SOIL SL: SLUDGE GW: GROUND WATER SW: SURFACE WATER WW: WASTE WATER

Turnaround Time <input checked="" type="checkbox"/> SJWT Standard is 10-20 work days <input type="checkbox"/> Rush turnaround available upon request and lab approval _____	Report Format <input checked="" type="checkbox"/> Standard <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	Comments/Special Instructions * HNO3 preserved upon receipt at laboratory		Cooler Temp °C
		Yes	No	

Sampled by: <i>D. Manaji</i> (Print)	Received by: <i>[Signature]</i> (Signature)	Date: 8/22/24	Date: 8/22/24	Time: 1400	Time: 1400
Relinquished by: <i>[Signature]</i> (Signature)	Received by: <i>[Signature]</i> (Signature)	Date:	Date:	Time:	Time:
Relinquished by: <i>[Signature]</i> (Signature)	Received by: <i>[Signature]</i> (Signature)	Date:	Date:	Time:	Time:

CHAIN OF CUSTODY RECORD

Customer:	Bancroft School
Contact	Steven Hitzel
Address:	311 Walton Ave Mount Laurel, NJ 08054
Phone:	Fax:
Office:	

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
www.sjwatertest.com
 NJ DEP Certification #08006



Lab ID#	Sample Location	Collection Date	Collection Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
W141600	FAUCET B108	8/22/24	0905	D	1 x 250	HNO3*	First Draw Lead	
W141601	FAUCET B108		0906	D	1 x 250	HNO3*	First Draw Lead	
W141602	FAUCET B110		0907	D	1 x 250	HNO3*	First Draw Lead	
W141603	FAUCET B110		0908	D	1 x 250	HNO3*	First Draw Lead	
W141604	FAUCET B112		0909	D	1 x 250	HNO3*	First Draw Lead	
W141605	FAUCET B112		0910	D	1 x 250	HNO3*	First Draw Lead	
W141606	FAUCET B115		0911	D	1 x 250	HNO3*	First Draw Lead	
W141607	FAUCET B117		0912	D	1 x 250	HNO3*	First Draw Lead	
W141608	FAUCET B117		0913	D	1 x 250	HNO3*	First Draw Lead	
W141609	FAUCET B118		0914	D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: D: DRINKING WATER A: AQUEOUS S: SOIL SL: SLUDGE G: GROUND WATER S: SURFACE WATER W: WASTE WATER

Turnaround Time	Report Format	Comments/Special Instructions	Cooler Temp
<input checked="" type="checkbox"/> SJWT Standard is 10-20 work days <input type="checkbox"/> Rush turnaround available upon request and lab approval _____	<input checked="" type="checkbox"/> Standard <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	* HNO3 preserved upon receipt at laboratory Yes _____ No _____	_____ °C

Sampled by: *D. Maguire*
 (Print)

Sampled by/Relinquished by: _____
 (Signature)

Relinquished by: _____
 (Signature)

Relinquished by: _____
 (Signature)

Date	Time	Received by:	Date	Time
8/22/24	1400	<i>[Signature]</i>	8/22/24	1400
Date	Time	Received by:	Date	Time
		<i>[Signature]</i>		
Date	Time	Received by:	Date	Time
		<i>[Signature]</i>		

CHAIN OF CUSTODY RECORD

Customer: Bancroft School
Contact: Steven Hitzel
Address: 311 Walton Ave
 Mount Laurel, NJ 08054
Phone: **Fax:**
Office:

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006



Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
W141610	FAUCET B118	8/22/24	0915	D	1 x 250	HNO3*	First Draw Lead	
W141611	FAUCET B120		0916	D	1 x 250	HNO3*	First Draw Lead	
W141612	FAUCET B120		0917	D	1 x 250	HNO3*	First Draw Lead	
W141613	FAUCET B123		0918	D	1 x 250	HNO3*	First Draw Lead	
W141614	FAUCET B123		0919	D	1 x 250	HNO3*	First Draw Lead	
W141615	FAUCET B125		0920	D	1 x 250	HNO3*	First Draw Lead	
W141616	FAUCET B125		0921	D	1 x 250	HNO3*	First Draw Lead	
W141617	FAUCET B127		0922	D	1 x 250	HNO3*	First Draw Lead	
W141618	FAUCET B127		0923	D	1 x 250	HNO3*	First Draw Lead	
W141619	FAUCET B104		0952	D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: D: DRINKING WATER A: AQUEOUS S: SOIL SL: SLUDGE GW: GROUND WATER SW: SURFACE WATER WW: WASTE WATER

<input checked="" type="checkbox"/> Turnaround Time SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	<input checked="" type="checkbox"/> Standard NJ DEP Reduced Deliverables NJ DEP Full Deliverables Electronic Data Deliverables PWTA Format	Comments/Special Instructions * HNO3 preserved upon receipt at laboratory	Cooler Temp °C Properly Preserved Yes No
---	--	--	---

Sampled by: *D. Mancini*
Sampled by/Relinquished by: *[Signature]* Date: *8/22/24* Time: *1400*
Relinquished by: *[Signature]* Date: _____ Time: _____
Relinquished by: *[Signature]* Date: _____ Time: _____

CHAIN OF CUSTODY RECORD

Customer:	Bancroft School
Contact	Steven Hitzel
Address:	311 Walton Ave Mount Laurel, NJ 08054
Phone:	Fax:
Office:	

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006



Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
	FAUCET B200	8/22/24	0852	D	1 x 250	HNO3*	First Draw Lead	
W141620	FAUCET B207	8/22/24	0849	D	1 x 250	HNO3*	First Draw Lead	
W141621	FAUCET B207		0848	D	1 x 250	HNO3*	First Draw Lead	
W141622	FAUCET B209 1		0847	D	1 x 250	HNO3*	First Draw Lead	
W141623	FAUCET B209 2		0846	D	1 x 250	HNO3*	First Draw Lead	
W141624	FAUCET B210		0845	D	1 x 250	HNO3*	First Draw Lead	
W141625	FAUCET B212		0844	D	1 x 250	HNO3*	First Draw Lead	
W141626	FAUCET B214		0843	D	1 x 250	HNO3*	First Draw Lead	
W141627	FAUCET B216		0842	D	1 x 250	HNO3*	First Draw Lead	
W141628	FAUCET B217		0841	D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: D=DRINKING WATER A=AQUEOUS S=SOIL SL=SLUDGE G=GROUND WATER S=SURFACE WATER W=WASTE WATER

Turnaround Time	<input checked="" type="checkbox"/> SJWT Standard is 10-20 work days <input type="checkbox"/> Rush turnaround available upon request and lab approval _____	Report Format	<input checked="" type="checkbox"/> Standard <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	Comments/Special Instructions	* HNO3 preserved upon receipt at laboratory	Cooler Temp	°C
Properly Preserved	<input type="checkbox"/> Yes <input type="checkbox"/> No						

Sampled by: (Print)	D. Mangini	Received by: (Signature)	[Signature]	Date	8/22/24	Date	8/22/24	Time	1400
Sampled by/Relinquished by: (Signature)	[Signature]	Received by: (Signature)	[Signature]	Date		Date		Time	
Relinquished by: (Signature)		Received by: (Signature)		Date		Date		Time	
Relinquished by: (Signature)		Received by: (Signature)		Date		Date		Time	

CHAIN OF CUSTODY RECORD

Customer: Bancroft School
Contact: Steven Hitzel
Address: 311 Walton Ave
 Mount Laurel, NJ 08054
Phone: **Fax:**
Office:

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006



Lab ID#	Sample Location	Collection Date	Time	Matrix	Pres.	No. of Bottles	Analysis Requested	Comments
W141629	FOUNTAIN B218A	8/22/24	0839	D	HNO3*	1 x 250	First Draw Lead	
W141630	FAUCET B218B		0838	D	HNO3*	1 x 250	First Draw Lead	
W141631	FAUCET B220		0837	D	HNO3*	1 x 250	First Draw Lead	
W141632	FAUCET B223		0836	D	HNO3*	1 x 250	First Draw Lead	
W141633	FAUCET B225		0835	D	HNO3*	1 x 250	First Draw Lead	
W141634	FAUCET B227 2		0834	D	HNO3*	1 x 250	First Draw Lead	
W141635	FAUCET B227 1		0833	D	HNO3*	1 x 250	First Draw Lead	
W141636	FAUCET B228		0832	D	HNO3*	1 x 250	First Draw Lead	
W141637	FAUCET B229		0831	D	HNO3*	1 x 250	First Draw Lead	
W141638	FAUCET B230		0830	D	HNO3*	1 x 250	First Draw Lead	

MATRIX ABBREVIATIONS: D: DRINKING WATER A: AQUEOUS S: SOIL SL: SLUDGE GW: GROUND WATER SW: SURFACE WATER WW: WASTE WATER

Turnaround Time
 Standard
 NJ DEP Reduced Deliverables
 NJ DEP Full Deliverables
 Electronic Data Deliverables
 PWTA Format

Report Format
 Standard
 NJ DEP Reduced Deliverables
 NJ DEP Full Deliverables
 Electronic Data Deliverables
 PWTA Format

Comments/Special Instructions
 * HNO3 preserved upon receipt at laboratory

Cooler Temp
 100 °C
 Properly Preserved: Yes

Sampled by: D. Marani (Print)
Sampled by/Relinquished by: (Signature)
Relinquished by: (Signature)
Relinquished by: (Signature)

Date: 8/22/24
Time: 1400

Date: 8/22/24
Time: 1400

Date:
Time:

CHAIN OF CUSTODY RECORD

Customer: Bancroft School
Contact: Steven Hitzel
Address: 311 Walton Ave
 Mount Laurel, NJ 08054
Phone:
Office:

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006



Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
W141629	Faucet B232	8/22/24	0840	D	1 x 250	HNO3*	First Draw Lead	
W141640	B Kitchen lounge		0850	D	1 x 250	HNO3*	First Draw Lead	
W141641	B up stairs fountain		0851	D	1 x 250	HNO3*	First Draw Lead	
W141642	B down stairs fountain		0858	D	1 x 250	HNO3*	First Draw Lead	
W141643	C 102 A		0925	D	1 x 250	HNO3*	First Draw Lead	
W141644	C 102 B		0926	D	1 x 250	HNO3*	First Draw Lead	
W141645	C 104		0927	D	1 x 250	HNO3*	First Draw Lead	
W141646	C 107		0935	D	1 x 250	HNO3*	First Draw Lead	
W141647	C 108		0936	D	1 x 250	HNO3*	First Draw Lead	
W141648	C 101 Art		0957	D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: D: DRINKING WATER A: AQUEOUS S: SOIL SL: SLUDGE G: GROUND WATER S: SURFACE WATER W: WASTE WATER

Turnaround Time <input checked="" type="checkbox"/> SJWT Standard is 10-20 work days <input type="checkbox"/> Rush turnaround available upon request and lab approval _____	Report Format <input checked="" type="checkbox"/> Standard <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	Comments/Special Instructions * HNO3 preserved upon receipt at laboratory		Cooler Temp °C Properly Preserved Yes No
		Received by: _____ (Signature)		

Sampled by: (Print) <u>D. Mancini</u>	Received by: (Signature) <u>[Signature]</u>	Date 8/22/24	Date 8/27/24	Time 1400	Time 1400
Sampled by/Relinquished by: (Signature) <u>[Signature]</u>	Received by: (Signature) _____	Date	Date	Time	Time
Relinquished by: (Signature) _____	Received by: (Signature) _____	Date	Date	Time	Time
Relinquished by: (Signature) _____	Received by: (Signature) _____	Date	Date	Time	Time

CHAIN OF CUSTODY RECORD

Customer: Bancroft School
Contact: Steven Hitzel
Address: 311 Walton Ave
 Mount Laurel, NJ 08054
Phone:
Office:

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006



Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
W141649	FAUCET C105	8/22/24	0928	D	1 x 250	HNO3*	First Draw Lead	
W141650	FAUCET C105		0929	D	1 x 250	HNO3*	First Draw Lead	
W141651	FAUCET C105		0930	D	1 x 250	HNO3*	First Draw Lead	
W141652	FAUCET C106		0931	D	1 x 250	HNO3*	First Draw Lead	
W141653	FAUCET C106		0932	D	1 x 250	HNO3*	First Draw Lead	
W141654	FAUCET C107		0933	D	1 x 250	HNO3*	First Draw Lead	
W141655	FAUCET C108		0934	D	1 x 250	HNO3*	First Draw Lead	
W141656	FAUCET C109		0937	D	1 x 250	HNO3*	First Draw Lead	
W141657	FAUCET C109		0938	D	1 x 250	HNO3*	First Draw Lead	
W141658	FAUCET C114		0940	D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: D: DRINKING WATER A: AQUEOUS S: SOIL SL: SLUDGE G: GROUND WATER S: SURFACE WATER W: WASTE WATER

Turnaround Time <input checked="" type="checkbox"/> SJWT Standard is 10-20 work days <input type="checkbox"/> Rush turnaround available upon request and lab approval _____	Report Format <input checked="" type="checkbox"/> Standard <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	Comments/Special Instructions * HNO3 preserved upon receipt at laboratory		Cooler Temp _____ °C
		Yes _____ No _____		

Sampled by: *D. Mancini*
 (Print)

Sampled by/Relinquished by: _____
 (Signature)

Relinquished by: _____
 (Signature)

Relinquished by: _____
 (Signature)

Received by: _____ (Signature)	Date 8/22/24	Date 8/22/24	Time 1400
Received by: _____ (Signature)	Date _____	Date _____	Time _____
Received by: _____ (Signature)	Date _____	Date _____	Time _____

CHAIN OF CUSTODY RECORD

Customer: Bancroft School
Contact: Steven Hitzel
Address: 311 Walton Ave
 Mount Laurel, NJ 08054
Phone:
Office:

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006



Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
W141658	FAUCET C116	8/22/24	0941	D	1 x 250	HNO3*	First Draw Lead	
W141659	FAUCET C117		0942	D	1 x 250	HNO3*	First Draw Lead	
W141660	FAUCET C118		0943	D	1 x 250	HNO3*	First Draw Lead	
W141661	FAUCET C119		0944	D	1 x 250	HNO3*	First Draw Lead	
W141662	FAUCET C120		0945	D	1 x 250	HNO3*	First Draw Lead	
W141663	FAUCET C121		0946	D	1 x 250	HNO3*	First Draw Lead	
W141664	FAUCET C126		0947	D	1 x 250	HNO3*	First Draw Lead	
W141665	FAUCET C127		0948	D	1 x 250	HNO3*	First Draw Lead	
W141666	FAUCET C128		0949	D	1 x 250	HNO3*	First Draw Lead	
	FAUCET C132			D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: D: DRINKING WATER A: AQUEOUS S: SOIL SL: SLUDGE GW: GROUND WATER SW: SURFACE WATER WW: WASTE WATER

Turnaround Time
 SJWT Standard is 10-20 work days
 Rush turnaround available upon request and lab approval _____

Report Format
 Standard
 NJ DEP Reduced Deliverables
 NJ DEP Full Deliverables
 Electronic Data Deliverables
 PWTA Format

Comments/Special Instructions
 * HNO3 preserved upon receipt at laboratory

Cooler Temp _____ °C

Properly Preserved
 Yes _____ No _____

Sampled by: *D. Manahi*
 (Print)

Sampled by/Relinquished by: *[Signature]*
 (Signature) Date: 8/22/24 Time: 1400

Relinquished by: _____
 (Signature) Date: _____ Time: _____

Relinquished by: _____
 (Signature) Date: _____ Time: _____

Received by: *[Signature]*
 (Signature) Date: 8/22/24 Time: 1400

Received by: _____
 (Signature) Date: _____ Time: _____

Received by: _____
 (Signature) Date: _____ Time: _____

CHAIN OF CUSTODY RECORD

Customer: Bancroft School
Contact: Steven Hitzel
Address: 311 Walton Ave
 Mount Laurel, NJ 08054
Phone:
Office:

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
www.sjwatertest.com
 NJ DEP Certification #08006



Lab ID#	Sample Location	Collection Date	Collection Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
W141667	FAUCET C131	8/22/24	0951	D	1 x 250	HNO3*	First Draw Lead	
W141668	FAUCET C130		0952	D	1 x 250	HNO3*	First Draw Lead	
W141669	FAUCET C134		0953	D	1 x 250	HNO3*	First Draw Lead	
W141670	FAUCET C WING KITCHEN		0954	D	1 x 250	HNO3*	First Draw Lead	
W141671	FAUCET G122 106 Art		0956	D	1 x 250	HNO3*	First Draw Lead	
W141672	C12		940	D	1 x 250	HNO3*	First Draw Lead	
W141673	C12		941	D	1 x 250	HNO3*	First Draw Lead	
W141674	C122		0947	D	1 x 250	HNO3*	First Draw Lead	
W141675	C128		0950	D	1 x 250	HNO3*	First Draw Lead	
W141676	C101		0955	D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: D: DRINKING WATER A: AQUEOUS S: SOIL SL: SLUDGE G: GROUND WATER S: SURFACE WATER W: WASTE WATER

Turnaround Time
 SJWT Standard is 10-20 work days
 Rush turnaround available upon request and lab approval _____

Report Format
 Standard
 NJ DEP Reduced Deliverables
 NJ DEP Full Deliverables
 Electronic Data Deliverables
 PWTA Format

Comments/Special Instructions
 * HNO3 preserved upon receipt at laboratory

Cooler Temp _____ °C
 Properly Preserved: Yes No

Sampled by: *D. Mangani*
 (Print)

Sampled by/Relinquished by: _____
 (Signature)

Relinquished by: _____
 (Signature)

Relinquished by: _____
 (Signature)

Date: 8/22/24
Time: 1400

Received by: _____
 (Signature)

Received by: _____
 (Signature)

Received by: _____
 (Signature)

Date: 8/22/24
Time: 1400

Date: _____
Time: _____

Date: _____
Time: _____