



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

Bancroft PEEP
101 Executive Drive
Moorestown, NJ 08057

www.sjwatertest.com
NJ DEP Certified Lab # 08006

Sample Location: Field Reagent Blank

Date Sampled: 08/22/24

Time Sampled: 12:00

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141510					
Lead	23-AUG-2024 13:40	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Peep Faucet 107

Date Sampled: 08/22/24

Time Sampled: 12:23

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141511					
Lead	23-AUG-2024 13:47	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Peep Faucet 108

Date Sampled: 08/22/24

Time Sampled: 12:24

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141512					
Lead	23-AUG-2024 13:53	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Peep Faucet 109

Date Sampled: 08/22/24

Time Sampled: 12:25

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141513					
Lead	23-AUG-2024 14:00	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Peep Faucet 111A

Date Sampled: 08/22/24

Time Sampled: 12:26

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141514					
Lead	23-AUG-2024 14:06	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Peep Faucet 112

Date Sampled: 08/22/24

Time Sampled: 12:27

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141515					
Lead	23-AUG-2024 14:13	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Peep Faucet 112

Date Sampled: 08/22/24

Time Sampled: 12:28

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141516					
Lead	23-AUG-2024 14:19	<2.00	ug/L	2.0	15.5	SM3113B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

09/04/2024

Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

Bancroft PEEP
101 Executive Drive
Moorestown, NJ 08057

www.sjwatertest.com
NJ DEP Certified Lab # 08006

Sample Location: Peep Faucet 112

Date Sampled: 08/22/24

Time Sampled: 12:29

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141517					
Lead	23-AUG-2024 14:39	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Peep Faucet 112

Date Sampled: 08/22/24

Time Sampled: 12:30

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141518					
Lead	23-AUG-2024 14:46	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Peep Faucet 112

Date Sampled: 08/22/24

Time Sampled: 12:31

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141519					
Lead	23-AUG-2024 14:52	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Peep Faucet 113

Date Sampled: 08/22/24

Time Sampled: 12:32

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141520					
Lead	23-AUG-2024 14:59	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Peep Faucet 113

Date Sampled: 08/22/24

Time Sampled: 12:33

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141521					
Lead	23-AUG-2024 15:05	3.74	ug/L	2.0	15.5	SM3113B

Sample Location: Peep Faucet 113

Date Sampled: 08/22/24

Time Sampled: 12:34

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141522					
Lead	23-AUG-2024 15:12	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Peep Faucet 113

Date Sampled: 08/22/24

Time Sampled: 12:35

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141523					
Lead	23-AUG-2024 15:19	<2.00	ug/L	2.0	15.5	SM3113B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

09/04/2024

Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

Bancroft PEEP
101 Executive Drive
Moorestown, NJ 08057

www.sjwatertest.com
NJ DEP Certified Lab # 08006

Sample Location: Peep Faucet 113

Date Sampled: 08/22/24

Time Sampled: 12:36

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141524					
Lead	23-AUG-2024 15:26	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Peep Faucet 119 Hall

Date Sampled: 08/22/24

Time Sampled: 12:22

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141525					
Lead	23-AUG-2024 15:32	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Peep Faucet 119 Laundry

Date Sampled: 08/22/24

Time Sampled: 12:23

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141526					
Lead	23-AUG-2024 15:39	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Peep Faucet 126

Date Sampled: 08/22/24

Time Sampled: 12:11

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141527					
Lead	26-AUG-2024 12:11	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Peep Faucet 126

Date Sampled: 08/22/24

Time Sampled: 12:12

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141528					
Lead	26-AUG-2024 11:25	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Peep Faucet 126

Date Sampled: 08/22/24

Time Sampled: 12:13

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141529					
Lead	26-AUG-2024 11:31	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Peep Faucet 126

Date Sampled: 08/22/24

Time Sampled: 12:14

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141530					
Lead	26-AUG-2024 11:38	<2.00	ug/L	2.0	15.5	SM3113B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

09/04/2024

Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

Bancroft PEEP
101 Executive Drive
Moorestown, NJ 08057

www.sjwatertest.com
NJ DEP Certified Lab # 08006

Sample Location: Peep Faucet 126

Date Sampled: 08/22/24

Time Sampled: 12:15

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141531					
Lead	26-AUG-2024 11:45	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Peep Faucet 127

Date Sampled: 08/22/24

Time Sampled: 12:16

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141532					
Lead	26-AUG-2024 11:51	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Peep Faucet 127

Date Sampled: 08/22/24

Time Sampled: 12:17

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141533					
Lead	26-AUG-2024 12:31	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Peep Faucet 127

Date Sampled: 08/22/24

Time Sampled: 12:18

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141534					
Lead	26-AUG-2024 12:38	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Peep Faucet 127

Date Sampled: 08/22/24

Time Sampled: 12:19

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141535					
Lead	26-AUG-2024 12:44	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Peep Faucet 127

Date Sampled: 08/22/24

Time Sampled: 12:20

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141536					
Lead	26-AUG-2024 12:51	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Peep Faucet 134

Date Sampled: 08/22/24

Time Sampled: 12:05

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141537					
Lead	26-AUG-2024 12:57	2.36	ug/L	2.0	15.5	SM3113B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

09/04/2024

Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

Bancroft PEEP
101 Executive Drive
Moorestown, NJ 08057

www.sjwatertest.com
NJ DEP Certified Lab # 08006

Sample Location: Peep Faucet 134

Date Sampled: 08/22/24

Time Sampled: 12:10

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141538					
Lead	26-AUG-2024 13:03	19.20	ug/L	2.0	15.5	SM3113B

Sample Location: Peep Faucet 139B

Date Sampled: 08/22/24

Time Sampled: 12:21

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W141539					
Lead	26-AUG-2024 13:10	<2.00	ug/L	2.0	15.5	SM3113B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

09/04/2024

Date

CHAIN OF CUSTODY RECORD

Customer: Bancroft School
Contact: Steven Hitzel
Address: 311 Walton Ave
 Mount Laurel, NJ 08054
Phone:
Office: Fax:

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
www.sjwatertest.com
 NJ DEP Certification #08006



Lab ID#	Sample Location	Collection Date	Time	Matrix	Comp	No. of Bottles	Pres.	Analysis Requested	Comments
W141510	FIELD BLANK	1220		X					
W141511	Peep Faucet 107	1224	1233	X		1 x 250	HNO3*	First Draw Lead	
W141512	Peep Faucet 108		1224	X		1 x 250	HNO3*	First Draw Lead	
W141513	Peep Faucet 109		1225	X		1 x 250	HNO3*	First Draw Lead	
W141514	Peep Faucet 111A		1226	X		1 x 250	HNO3*	First Draw Lead	
W141515	Peep Faucet 112		1227	X		1 x 250	HNO3*	First Draw Lead	
W141516	Peep Faucet 112		1228	X		1 x 250	HNO3*	First Draw Lead	
W141517	Peep Faucet 112		1229	X		1 x 250	HNO3*	First Draw Lead	
W141518	Peep Faucet 112		1230	X		1 x 250	HNO3*	First Draw Lead	
W141519	Peep Faucet 112		1231	X		1 x 250	HNO3*	First Draw Lead	
W141520	Peep Faucet 113		1232	X		1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: D: DRINKING WATER A: AQUEOUS S: SOIL SL: SLUDGE G: GROUND WATER SW: SURFACE WATER WW: WASTE WATER

Turnaround Time <input checked="" type="checkbox"/> SJWT Standard is 10-20 work days <input type="checkbox"/> Rush turnaround available upon request and lab approval _____	Report Format <input checked="" type="checkbox"/> Standard <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	Comments/Special Instructions * HNO3 preserved upon receipt at laboratory	Cooler Temp °C
	Yes No	Properly Preserved	Yes No

Sampled by: (Print) D. Mancini

Sampled by/Relinquished by: (Signature) [Signature] **Date:** 12/24/24 **Time:** 1403

Relinquished by: (Signature) [Signature] **Date:** 12/24/24 **Time:** 1403

Relinquished by: (Signature) _____ **Date:** _____ **Time:** _____

CHAIN OF CUSTODY RECORD

Customer: Bancroft School
Contact: Steven Hitzel
Address: 311 Walton Ave
 Mount Laurel, NJ 08054
Phone: _____
Office: _____

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006



Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
W141521	Peep Faucet 113	8/22/24	1233	D	1 x 250	HNO3*	First Draw Lead	
W141522	Peep Faucet 113		1234	D	1 x 250	HNO3*	First Draw Lead	
W141523	Peep Faucet 113		1235	D	1 x 250	HNO3*	First Draw Lead	
W141524	Peep Faucet 113		1236	D	1 x 250	HNO3*	First Draw Lead	
W141525	Peep Fountain 119 Hall		1222	D	1 x 250	HNO3*	First Draw Lead	
W141526	Peep Slop Sink 119 Laundry		1223	D	1 x 250	HNO3*	First Draw Lead	
W141527	Peep Faucet 126		1211	D	1 x 250	HNO3*	First Draw Lead	
W141528	Peep Faucet 126		1212	D	1 x 250	HNO3*	First Draw Lead	
W141529	Peep Faucet 126		1213	D	1 x 250	HNO3*	First Draw Lead	
W141530	Peep Faucet 126		1214	D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER AQUEOUS SISOIL SL/SLUDGE GW/GROUND WATER SWS/SURFACE WATER WW/WASTE WATER

Turnaround Time
 SJWT Standard is 10-20 work days
 Rush turnaround available upon request and lab approval _____

Report Format
 Standard
 NJ DEP Reduced Deliverables
 NJ DEP Full Deliverables
 Electronic Data Deliverables
 PWTA Format

Comments/Special Instructions
 * HNO3 preserved upon receipt at laboratory

Cooler Temp
 Properly Preserved: Yes _____ No _____

Sampled by: *D. Magrini*
 (Print)

Sampled by/Relinquished by: _____
 (Signature)

Relinquished by: _____
 (Signature)

Relinquished by: _____
 (Signature)

Received by: _____
 (Signature) Date: 8/22/24 Time: 1400

Received by: _____
 (Signature) Date: _____ Time: _____

Received by: _____
 (Signature) Date: _____ Time: _____

CHAIN OF CUSTODY RECORD

Customer: Bancroft School
Contact: Steven Hitzel
Address: 311 Walton Ave
 Mount Laurel, NJ 08054
Phone:
Office:

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
www.sjwatertest.com
 NJ DEP Certification #08006



Lab ID#	Sample Location	Collection Date	Collection Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
W141531	Peep Faucet 126	8/22/24	1215	D	1 x 250	HNO3*	First Draw Lead	
W141532	Peep Faucet 127		1216	D	1 x 250	HNO3*	First Draw Lead	
W141533	Peep Faucet 127		1217	D	1 x 250	HNO3*	First Draw Lead	
W141534	Peep Faucet 127		1218	D	1 x 250	HNO3*	First Draw Lead	
W141535	Peep Faucet 127		1219	D	1 x 250	HNO3*	First Draw Lead	
W141536	Peep Faucet 127		1220	D	1 x 250	HNO3*	First Draw Lead	
W141537	Peep Faucet 134		1205	D	1 x 250	HNO3*	First Draw Lead	
W141538	Peep Faucet 134		1210	D	1 x 250	HNO3*	First Draw Lead	
W141539	Peep Faucet 139B		1221	D	1 x 250	HNO3*	First Draw Lead	
	Peep Faucet 111		1222	D	1 x 250	HNO3*	First Draw Lead	No Stnk

MATRIX ABBREVIATIONS: D: DRINKING WATER, A: AQUEOUS, S: SOIL, SL: SLUDGE, G: GROUND WATER, SW: SURFACE WATER, WW: WASTE WATER

Turnaround Time
 Standard
 NJ DEP Reduced Deliverables
 NJ DEP Full Deliverables
 Electronic Data Deliverables
 PWTA Format

Report Format
 Standard
 NJ DEP Reduced Deliverables
 NJ DEP Full Deliverables
 Electronic Data Deliverables
 PWTA Format

Comments/Special Instructions
 * HNO3 preserved upon receipt at laboratory

Cooler Temp
 Properly Preserved
 Yes No

Sampled by: *D. Maguire*
 (Print)

Sampled by/Relinquished by:
 (Signature)

Relinquished by:
 (Signature)

Relinquished by:
 (Signature)

Date	Time	Received by:	Date	Time
8/22/24	1400	<i>[Signature]</i>	8/22/24	1400
		<i>[Signature]</i>		
		<i>[Signature]</i>		