



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab # 08006

Bancroft - Voorhees Pediatric Facility
1304 Laurel Oak Road
Voorhees, NJ 08043

Sample Location: Field Reagent Blank

Date Sampled: 09/10/24

Time Sampled: 07:20

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W142335					
Lead	16-SEP-2024 16:03	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Class 3

Date Sampled: 09/10/24

Time Sampled: 07:23

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W142336					
Lead	16-SEP-2024 15:44	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Class 3 - Toliet

Date Sampled: 09/10/24

Time Sampled: 07:24

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W142337					
Lead	16-SEP-2024 16:10	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Class 1

Date Sampled: 09/10/24

Time Sampled: 07:24

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W142338					
Lead	16-SEP-2024 16:16	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Class 2

Date Sampled: 09/10/24

Time Sampled: 07:25

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W142339					
Lead	16-SEP-2024 16:23	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Class 4

Date Sampled: 09/10/24

Time Sampled: 07:30

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W142340					
Lead	16-SEP-2024 16:29	<2.00	ug/L	2.0	15.5	SM3113B

Sample Location: Class 5

Date Sampled: 09/10/24

Time Sampled: 07:30

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W142341					
Lead	16-SEP-2024 16:36	<2.00	ug/L	2.0	15.5	SM3113B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

09/17/2024

Date



www.sjwatertest.com
NJ DEP Certified Lab # 08006

**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

Bancroft - Voorhees Pediatric Facility
1304 Laurel Oak Road
Voorhees, NJ 08043

Sample Location: Class 6

Date Sampled: 09/10/24

Time Sampled: 07:31

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W142342					
Lead	16-SEP-2024 16:42	2.46	ug/L	2.0	15.5	SM3113B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

09/17/2024

Date

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC

4077 South Black Horse Pike

Williamstown, NJ 08094

Phone: 856-875-3506 Fax: 856-875-3507

www.sjwaterest.com

NJ DEP Certification #08006



Customer: Bancroft - Voorhees Pediatric Facility

Contact: Colleen Valentino

Address: 1304 Laurel Oak Road

Voorhees, NJ 08043

Phone:

Fax:

Office:

Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
W142335	Field Reagent Blank	9/10/20	7:20	D	1 x 250	HNO3*	First Draw Lead	
W142336	Class 3	9/10	7:23	D	1 x 250	HNO3*	First Draw Lead	
W142337	Toilet Class 3	9/10	7:24	D	1 x 250	HNO3*	First Draw Lead	
W142338	Class 1	9/10	7:24	D	1 x 250	HNO3*	First Draw Lead	
W142339	Class 2	9/10	7:25	D	1 x 250	HNO3*	First Draw Lead	
W142340	Class 4	9/10	7:30	D	1 x 250	HNO3*	First Draw Lead	
W142341	Class 5	9/10	7:30	D	1 x 250	HNO3*	First Draw Lead	
W142342	Class 6	9/10	7:31	D	1 x 250	HNO3*	First Draw Lead	
				D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER AQUEOUS SISOIL SL/SLUDGE GW/GROUND WATER SW/SURFACE WATER WW/WASTE WATER

Turnaround Time SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Report Format Standard _____ NJ DEP Reduced Deliverables _____ NJ DEP Full Deliverables _____ Electronic Data Deliverables _____ PWTA Format _____		Comments/Special Instructions * HNO3 preserved upon receipt at laboratory	Cooler Temp °C
			Yes	No

Sampled by:
(Print) *Dana Sheehan*

Sampled by/Relinquished by:
(Signature) *[Signature]*

Relinquished by:
(Signature) *[Signature]*

Relinquished by:
(Signature) *[Signature]*

Date 9/12

Time 9:25

Received by:
(Signature) *[Signature]*

Date 9/12/24

Time 0925

Received by:
(Signature) *[Signature]*

Date

Time

Received by:
(Signature)

Date

Time

Received by:
(Signature)