



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

Bancroft PEEP
101 Executive Drive
Moorestown, NJ 08057

www.sjwatertest.com
NJ DEP Certified Lab # 08006

Sample Location: RM134 Hand Wash

Date Sampled: 06/19/25

Time Sampled: 06:15

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	X150407					
Lead	23-JUN-2025 13:22	15.47	ug/L	2.0	15.5	SM3113B

Sample Location: RM134 Dish Sink

Date Sampled: 06/19/25

Time Sampled: 06:15

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	X150408					
Lead	23-JUN-2025 13:28	<2.00	ug/L	2.0	15.5	SM3113B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

06/26/2025

Date

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC

4077 South Black Horse Pike
Williamstown, NJ 08094

Phone: 856-875-3506 Fax: 856-875-3507
www.sjwatertest.com

NJ DEP Certification #08006

Customer:	Bancroft Peep
Contact:	Steven Hitzel
Address:	101 Executive Drive Moorestown, NJ 08057
Phone:	609-577-5333
Office:	0

Lab ID#	Sample Location	Collection Date	Time	Comp	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
X150407	NM 134 HAND WASHT RACEY	6/19/25	6:15 AM	X	D	1 x 250	HNO3*	Lead	
				X	D	1 x 250	HNO3*	Lead	
X150408	NM 134 DISINFECTION FAVEY	6/19/25	6:15 AM	X	D	1 x 250	HNO3*	Lead	
				X	D	1 x 250	HNO3*	Lead	
				X	D	1 x 250	HNO3*	Lead	
				X	D	1 x 250	HNO3*	Lead	
				X	D	1 x 250	HNO3*	Lead	
				X	D	1 x 250	HNO3*	Lead	
				X	D	1 x 250	HNO3*	Lead	
				X	D	1 x 250	HNO3*	Lead	
				X	D	1 x 250	HNO3*	Lead	

MATRIX ABBREVIATIONS: D: DRINKING WATER A: AQUEOUS S: SOIL SL: SLUDGE GW: GROUND WATER SW: SURFACE WATER WW: WASTE WATER

Turnaround Time SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Report Format Standard ____ NJ DEP Reduced Deliverables ____ NJ DEP Full Deliverables ____ Electronic Data Deliverables ____ PWTA Format	Comments/Special Instructions ____ ____ * HNO3 preserved upon receipt at laboratory	Cooler Temp ____ °C
	Properly Preserved Yes No		

Sampled by: Steven Hitzel (Print)		Date	Time
Sampled by/Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Time